



**QUESTIONS & ANSWERS  
JAIL CONTROL SYSTEM**  
Requisition No. PD-041422

**APRIL 6, 2022**

1. **Does the current system monitor if doors are opened or closed?** The control boards are designed to show if doors are secured (locked) or open. Currently, there are multiple doors showing opened when they are closed and vice versa.
2. **Do the sallyport doors have card readers on them or just controlled by the head end?** There are no card readers in the sallyport. The only card reader in the jail is to gain entrance to the booking counter/control pod areas.
3. **Is there a requirement for new system to have redundancy or a failover server in the event of a system crash?** We did not write failover or redundancy requirements into the RFP, but it would be a good idea to include it, though.
4. **I also do not see in the RFP to have spare parts on hand for maintenance issues. We would suggest having a minimum stock of key components on hand for emergency use because some parts may take a while to order if something goes wrong.** We are in favor of having spare parts on hand. Please include this as a separate line item on the proposal.

Logan Eberly  
Purchasing Agent  
City of Foley