



Terry McKee, IS & Procurement Director
 901 Broadway, N.E. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

SOLICITATION NAME	Generator Maintenance & Repair Services Q1618	ADDENDUM NUMBER	1	DATE	01-28-16
--------------------------	---	------------------------	---	-------------	----------

KCDC is using this addendum to answer the questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bold**, and the answers follow immediately below.

1.	How are these units located? These questions are important for the load bank test. Indoors or Outdoors? Outdoors.
2.	If outdoors are any of the units located on the roof top? If so, how many stories? All are at the ground level.
3.	If indoors, how close approximately can we get our service truck to the unit? Not applicable.
4.	Is there a particular month of the year when you would prefer that the maintenance and load bank be performed? No.
5.	I almost have the quote worked up but I need to clarify one point with you. The way the sheet is structured it appears that there are two generators at Cagle and North Gate but the rest of the document and our own repair records indicate 1 unit per location. It may be that that there are two separate transfer switches at these two but that typically does not require a second Load Bank or PM charge. Could you give me your guidance on how you want these quoted? That is a typo-there is one generator at each of these sites.

End of Addendum