

ADDENDUM NO. 1

DATE: August 27, 2021

TO: All Submitters

FROM: Penny Owens, Purchasing Agent

SUBJECT: Addendum No. 1 – Cured-In-Place Pipe (CIPP)
Infrastructure Rehabilitation Improvements Design

LOIS TO BE OPENED: September 3, 2021, at 11:00:00 a.m. (Eastern)

This addendum responds to questions received from potential submitters. This addendum hereby becomes a part of the Contract Document and modifies the original specifications as noted.

Question #1: Will the selected engineering consultant or the city engineering staff perform the conditions assessment of the existing stormwater infrastructure? Additionally, if the selected consulting firm is performing the conditions assessment, does the City of Knoxville have an “in-house” classification system or an adopted classification system that corresponds to a third-party certification? An example of this would be NASSCO pipeline (PACP), manhole (MACP), and lateral (LACP).

Response: The consultant will not be required to do a conditions assessment for the purposes of ranking the importance or creating a timeline of when a particular pipe segment needs to be rehabilitated. However, the consultant will be required to review all materials received from city engineering such as maps, photos, videos, etc., to assess the condition of each pipe and produce a complete design for full CIPP rehabilitation.

END OF ADDENDUM NO. 1