



JACKSON COUNTY
FINANCE DEPARTMENT
67 Athens Street
Jefferson, Georgia 30549-1401

PHONE: (706) 367-6313 FAX: (706) 367-2505

Trey Wood
DIRECTOR

Date: October 16, 2017

To: Generator Services Companies

From: Myrna Yarbrough, Purchasing Manager

RE: Addendum #3 to Jackson County ITB 170021, Furnish and Install Generators

1. Addendum #3 is issued to inform all companies that have a copy of ITB 170021, Furnish and Install Generators.
2. All other terms and conditions in ITB 170021 remain unchanged.
3. Any inquiries concerning Addendum #3 should be addressed to Myrna Yarbrough, Purchasing Manager, 706-367-6309 or via email at myarbrough@jacksoncountygov.com
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission. Bidders must acknowledge receipt of addenda on the request for proposal form.
5. The size of the UPS currently at the Administration/IT Building is 30 KV, 208 VAC.
6. Specification for the engine for the generator at the South Jackson EMS Station is hereby modified to be propane, not diesel. Delete item 11. The fuel tank is not required for the propane generator, as an existing tank at the location will be used.
7. Answers to additional contractor questions are as follows: PE stamped drawings are not required. All ATS are NEMA3R. Contractor may be on site at all four locations at same time, with installation occurring at same time. Only one permit will need to be pulled. Warranty begins after generator installation and start up. Training may be held at one location. Generator testing may be done by installation contractor or by a qualified third party. The county will be responsible for switching gas meters, if needed. Generator package and automatic transfer switches should be NFPA 110 compliant. Generators should be 1800 rpm or greater.