

City of
SHELBYVILLE
Tennessee

INVITATION TO BID
ADDENDUM

January 18, 2022

To: Potential Bidders

A correction is necessary to the Invitation to Bid Request dated January 11, 2022 from the City of Shelbyville for "DOG PARK FENCE INSTALLATION AT H. V. GRIFFIN PARK".

Correction:

Pages 6 and 7 - Specifications

Attached please find addendum details for:

Section 2.01 Materials A

Section 2.02 Components A, B, C and G

Section 2.04 Finishes A

Section 3.01 Installation J

We apologize for any inconvenience.

Please contact Purchasing Director Lori Saddler at 931-684-2691 if you have any further questions.

Lori Saddler
Purchasing / IT Director

Addendum:

Part 2 Products

2.01 Materials

A. ASTM 1043 is acceptable

2.02 Components

A. Line Posts: 2 inch diameter is acceptable

B. Corner and Terminal Posts: 3.0 inch is acceptable

C. Gate Posts: 4 inch diameter posts for the drive through gate is acceptable.
3 inch posts for all other gate posts is acceptable

G. Tension Wire: 7 gage is acceptable

2.04 Finishes

A. 1.2 oz/sq ft is acceptable

3.01 Installation

J. Terminal posts at intervals not to exceed 500 feet.