



ADDENDUM NO. **1**
Issue Date: September 9, 2022
Project Name: Central Regional WWTF Roof Replacement
Bid Number: 2022041
Bid Opening Date: **September 20, 2022**

This addendum is being released to answer questions received to date. The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.**

Questions & Answers

1. Are you willing to accept any alternatives to the roofing materials requested on this roof system? Sarnafil is 8 months out to get materials and Fibertite is not available at all. **We would be willing to accept Carlisle Sure-Flex 60-mil KEE HP system as an alternate.**