

“City of Havelock
Pineview Lift Station Repair”
Addendum 2
June 26, 2020

Questions Received

1. Can the city provide a lead-paint analysis to confirm the coating's composition?



Contractors are to include in base bid the cost for lead paint analysis. A new bid sheet has been attached to this addendum to include addition 1. Addition 1 will be added to the base bid price if lead paint is found during testing.

2. Due to the moisture conditions in the dry-well, we are concerned the fiberglass may not bond to the existing walls and structure. Can the contractor substitute an epoxy based lining in lieu of fiberglass? Additionally, how high does the owner want the contractor to coat up the wall?

Epoxy base lining will be allowed. Contractor must submit product data to City for review and approval before use. Provide coating on the walls for a distance of 1' (one foot) from floor level.

3. Does the city want the contractor to add sacrificial anodes to the drywell to help inhibit additional corrosion to the drywell structure?



Sacrificial anodes will not be required.

4. Can you provide GIS mapping of the site indicating the two upstream MH's to be bypassed during construction.



5. Can you provide rim and invert elevations for the MH's to be bypassed and associated pipe size.

MH P84 is 7' deep on a 8' line. MH P75 is 9' deep and the rim sits approximately 5' above the ground on a 12" line.

6. Can Pineview Street be closed during bypass pumping operations?

The road can be closed to through traffic, but access must be maintained for affected residents.

Bid Sheet

Base Bid: _____

Addition 1 _____

NC Sales Tax: _____

Delivery Cost (if applicable): _____

Total Cost to City: _____

Bids must include an itemized schedule by quantity, unit price and total for each work element.

Company Name: _____

Company Address: _____

Contact Person: _____

Telephone Number: _____

NC Contractor's License Type and Number: _____

Number of Addendums Acknowledged (circle one): N/A 1 2 3 4

As of the date listed below, the vendor or bidder listed above is compliant with N.C.G.S. 147-86.42-84, the Iran Divestment Act and the Companies Boycotting Israel Act.

Authorized Signature: _____

Print Name of Authorized Signature: _____

Title: _____

Address Bid to: Lee Tillman, Director of Finance
City of Havelock
P.O. Drawer 368
1 Governmental Avenue
Havelock, NC 28532
Bids@Havelocknc.us

Please indicate the Bid name on the outside of the envelope.