

Questions for Summer 2019 Resurfacing

- 1) Cardinal Drive, Eagle Drive, and Dove Court all are missing from the Bid Sheet regarding to items and quantities.
 - a. These items have been added to the bid sheets with the quantities and will come out with the addendum
- 2) Scott Court's quantities in the Bid Pack do not match the area covered in the Strip Maps. Is there extra area not shown in the Maps?
 - a. The quantities for Scott Court have been updated in the bid docs.
- 3) The Leveling Allowance Item is in Square Yards. What asphalt thickness should be used for this area? How many tons?
 - a. The leveling allowance has been reduced in quantity and changed from SY to TON
- 4) Are driveways included in the quantities for the asphalt paving?
 - a. Driveway quantities are not included for the asphalt paving. We do not intend to mill or pave the driveways.