

BUSCH DRIVE ADDEDUM ONE

1. On the notes of the "Sewer and Force Main Details" plans, it calls out for a metal canopy over the lift station control panel. Do we supply and install this metal canopy or is this not included in our scope since the City is handling the electrical? – No. The contractor will not be responsible for installing a metal canopy.
2. Do we need to make a new gravel road with a culvert coming off Busch Dr. or could the access road come off the existing gravel road? – The contractor will use the existing drive but will need to lay a small amount of gravel and pipe for drainage.
3. Are we responsible for supplying and installing a slide gate and fence for the lift station?- Yes the contractor will be responsible for supplying and installing a slide gate and fence.