



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: March 3, 2022
TO: Prospective Respondents
FROM: Amy Lucey, Procurement Specialist
SUBJECT: Addendum #3 to Invitation For Bid, # 37655, Resurface L-512 Recreation Area Parking Lot

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: Will there be any milling required?

A1: No milling is required

Q2: FDOT specs for striping has an approved product list for pain and requires glass beads for reflectivity. Is this required or will any waterborne pavement paint with no beads be sufficient?

A2: Waterborne pavement paint with no beads is sufficient.

Q3: To confirm, we can NOT close the lot and do the project all at once?

A3: The District has agreed to close the parking lot for up to two days during the middle of the week preferably between Monday – Wednesday. The site should be open to the public beginning Thursday morning.

NOTE: The Bid Due Date **remains** 2:00 p.m., **Thursday, March 31, 2022**

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.