



**PURCHASING
AND MATERIALS
MANAGEMENT**

**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum 01
May 31, 2022
IFB 22-B0045
Storage Building with Lean-To**

The purpose of this Addendum 01 to IFB 22-B0045 for Storage Building with Lean-To, dated May 18, 2022, is to list the key points of discussion from the mandatory site visit.

- The new concrete slab under the lean-to will be 22'L x 10'W x 6" deep, 4000 PSI, poured in temperatures above 50 degrees.
- The storage building does not require electrical or plumbing work.
- The colors specified for the storage building and lean-to are to match the colors of the existing building.
- Contractor is advised that there may be other projects going on in the area during the same time frame as this project.
- Additional questions are due no later than 12:00 noon on Tuesday, June 7, 2022. Questions may be submitted via e-mail to asowers@cityofmyrtlebeach.com. All questions received by the deadline will be answered via addendum.
- Sealed bids are due in the Purchasing Office no later than 3:00PM (local time) on Tuesday, June 14, 2022. No electronic submissions will be accepted. The City of Myrtle Beach is not responsible for late or misdirected mail.
- The mandatory site visit sign-in sheet is attached and is hereby made part of this addendum.


Please send in your bid in a sealed envelope to the address below:

City of Myrtle Beach
3231 Mr. Joe White Avenue
Myrtle Beach, SC 29577
Attn: Purchasing Division/Ann Sowers

MANDATORY PRE-BID: Tuesday, May 31, 2022 @ 1:30 PM (local time)

BID: IFB 22-30045/Storage Building with Lean-To

BID OPENING: Tuesday, June 14, 2022 @ 3:00 PM (local time)
Please sign in

<u>Company Name</u>	<u>Representative</u>
1) <u>Stalvey Const CO Inc</u>	<u>Daron Stalvey</u>
<u>843-347-9453</u>	<u></u>
<u>Phone/Fax</u>	<u>Signature</u>
<u>Stalvey Concrete @ Yahoo.com</u>	<u>Yahoo.com</u>
<u>Email Address</u>	