

## ADDENDUM NO. 1

DATE: August 9, 2022

TO: All Potential Bidders

FROM: Suzanne Daws, Procurement Specialist, City of  
Knoxville

SUBJECT: Addendum No. 1 – Traffic Signal Cantilever Supports,  
Gleason & Downtown West

BIDS TO BE OPENED: August 17, 2022, at 11:00:00 a.m. (Eastern Time)

This addendum is being published to answer questions from bidders and becomes a part of the Contract Document and modifies the original specifications as noted.

**Question #1: Intersection plan page shows a 6C Power Feed running to Pole MA-1. Is this line running above ground? If so, we will need to be supplied the attachment height and Tension Load, before sending out to the manufacturer to review.**

**Response:** Yes, the power feed will be running overhead from the existing Knoxville Utilities Board (KUB) pole to the new pole MA-1.

**Question #2: Should we include Tether Wire Clamps for poles MA-1 & SP-1?**

**Response:** Yes, the City would prefer tether wire clamps on both poles.

**Question #3: For loading purposes we intend to use 8' x 18" for Street Name Sign sizing. Please advise if you would like adjusted.**

**Response:** 8' x 18" will be acceptable.