

**ADDENDUM NO. 1**  
TO THE CONTRACT DOCUMENTS FOR  
**SANDY CREEK DRIVE – CULVERT REPLACEMENT**  
**CITY OF WILSON, NORTH CAROLINA**  
**NOVEMBER 8, 2021**

---

**To All Bidders:**

This addendum is issued to modify or clarify the previously issued bid documents and/or given for informational purposes, and is herein made a part of the bid documents. This addendum must be acknowledged on the appropriate page of the contract Bid Form. Failure to acknowledge this addendum may subject the bidder to disqualification of his bid.

It is the responsibility of all bidders and all individual subcontractors to adhere to the following modifications, clarifications and/or information:

1. Revised Bid Set dated 11-8-2021 shall be utilized. The revision resolves the discrepancy of the bottomless culvert size between the plan sheet and the profile. The correct size is 5'x8'.
2. Bidders shall utilize the Revised Bid Form Dated 11/8/2021.

**END OF ADDENDUM NO. 1**

**Robert S. Bartlett, PE**  
Bartlett Engineering & Surveying, PC