

Addendum No. 2

November 18, 2019

An Addition for:

Grand Oaks Elementary Gymnasium

To: Prime contractors and all others to whom drawings and specifications have been issued. This Addendum forms part of the Contract Documents. It supplements and modifies them as follows:

A. Specifications:

Section 07 53 30

Rubber Membrane Roofing

Part 1, 1.01, A is modified to read "Furnish and install a fully adhered rubber membrane roofing system as manufactured by GENFLEX, 250 West 96th Street, Indianapolis, IN, where shown on the drawings, including insulation, wood grounds, and wood cleats required to secure roofing in place and miscellaneous items at necessary for a complete warranted installation. New 60 mil EPDM roofing must match the existing EPDM roofing manufacture, be installed by a GENFLEX authorized roofing installer, and be installed such that the warranty on the existing adjacent GENFLEX EPDM gymnasium roof to remain is maintained."

Part 2.01, C Elastomeric Sheet Roofing System Components, 1 thru 20. Components used must be recommended for use with GENFLEX EPDM roofing by GENFLEX manufacturer.

B. Questions:

- **Question:**
Are there original sprinkler drawings that contractors can have access to?
- **Response:** Original sprinkler drawings for the building are not available at this time.

C. Substitution Requests:

- **Specification Section 07 53 30**

Rubber Membrane Roofing

A substitution request was received for specification section 07 53 30 proposing to provide products by Johns Manville, A Berkshire Hathaway Company. Substitution request is not approved per owner direction.

End of Addendum

Job Number: 170759

Chattanooga
University Tower
651 E. Fourth Street, Suite 500
Chattanooga, TN 37403
(o) 423.756.5046

Knoxville
299 N. Weisgarber Road
Knoxville, TN 37919
(o) 865. 584.0999

www.mbicompanies.com

Florida
100 Colonial Center Parkway, Suite 230
Lake Mary, FL 32746
(o) 407.585.0330
Architecture: AA26000828
Interiors: IB26000665