

CITY OF HANAHAN – ADDENDUM NO. 2

COH#--071717

TO: ALL BIDDERS

FROM: KITTY FARIAS, PURCHASING AGENT

DATE: 08/03/2017

BID NO.: **COH#-071717**

BID TITLE: CITY OF HANAHAN FIRE DEPARTMENT #3
ROOF AND INTERIOR KITCHEN REPAIR

1. What area is to be re-roofed?

Install at least a 60mil TPO Roofing System on the **flat roof** which also extends over the kitchen area where damages incurred. These areas are highlighted in the attachment.

2. What is the reference to “fiberglass gutters”

See Attached Site Inspection report from FEMA attached to Addendum No.1.

This is a **recommendation** from FEMA only

3. Please price a separate quote for the following types of gutter material(s):

- Fiberglass gutters (FEMA) recommendation
(with color matching building)
- 24 gage galvalume
(with color matching building)

4. Mfg. Warranty:

Warranties for materials should be the Manufacturers standard warranty on their products **ONLY**. (No extended warranties are requested)

5. Cabinet/Counter Allowance:

(\$5,000.00)

***** Please sign the acknowledgement on page 2 and attach to bid submission. Failure to acknowledge the Addendum may subject the Contractor to disqualification.***

PLEASE SIGN AND ATTACH ACKNOWLEDGEMENT WITH BID SUBMISSION

See Attached

END ADDENDUM NO. 2

CITY OF HANAHAN – ADDENDUM NO. 2
CITY OF HANAHAN FIRE DEPARTMENT #3
ROOF AND INTERIOR KITCHEN REPAIR – COH#-071717

The Bidder/Offeror acknowledges the Addendum and it has been received and incorporated into the Bid:

Addendum No. 2

Dated _____, Signature _____

Respectfully submitted by: _____
(FIRM NAME)

Signature: _____

Representative Name: _____

Title: _____

Address: _____

Date: _____

Telephone No: _____


Fax Number: _____

Email: _____

The area highlighted in YELLOW is the outlay of the area of roof to be repaired.

The area highlighted in RED are for gutter installation.

NIC = NOT INCLUDED IN CONTRACT



Yellow - Roof Repair
Red - Gutter Installation