



Jackson County Board of Commissioners

67 Athens Street
Jefferson, Georgia 30549
Phone: (706) 367-6309
Fax: (706) 708-2505
Email: agamble@jacksoncountygov.com

Date: March 29, 2023

To: Paving Companies

From: Alisha Gamble, Finance Director

RE: Addendum 2 to Jackson County ITB 230002, Road Patching & Resurfacing Program, Jackson County

1. Addendum 2 is hereby issued to answer questions, per attached.
2. All other terms and conditions in ITB 230002 remain unchanged.
3. Any inquiries concerning Addendum 2 should be made to Alisha Gamble, Finance Director, at (706)367-6313 or via email at agamble@jacksoncountygov.com
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #2" at bottom of the proposal.

See below questions:

- 1) Under General Condition it states: L. NON-COLLUSION CERTIFICATION: "Each bidder shall execute an affidavit of non-collusion." Will this form be provided by the county?
- 2) GDOT issued a Bulletin last September, which I have attached to this email. Will the county allow the use of Antistripping Additives instead of Hydrated Lime in the mixes?
- 3) Does the county require the use of MTV's or shuttle buggy for this project?
- 4) What are work hours for this project?
- 5) On the roads that require edge milling only and overlay, will the county adjust manholes and utilities to match the new elevation or will that be the responsibility of the contractor?
- 6) If the contractor is to raise utilities, can the contractor use industry standard metal risers to match elevations?
- 7) On page 3 it states: "1 original and 3 copies of the Request For Bid must be submitted", however, on page 10, Identification of Bid Envelopes it states: "The signed Bid should be returned in a separate envelope or package". Does this mean the county request that the contractor put the Bid Schedule only in a separate envelope, and provide 1 original and 3 copies in addition to that? Please advise.
- 8) Will the Bid results be publicly read out on April 4th?

See below answers:

1. Paragraph L is amended to delete "each bidder shall execute an affidavit of non-collusion".
2. Antistripping additive is acceptable.
3. No shuttle buggy required
4. No hour restrictions
5. County will adjust manholes to match elevations
6. Handle in house
7. 1 original and 3 copies can be submitted in one envelope, with the bide bond and bid schedule.
8. Yes