



**ADDENDUM NUMBER ONE
FOR CONTRACT FY2019-150**

DATE: April 12, 2019
TO: ALL BIDDERS OF RECORD
FROM: Lyn Majeski, Purchasing Manager
BID FOR: **PINEWOOD PARK SIDEWALK PROJECT**

This addendum forms a part of and modifies the bidding specifications for the above item for the City of Oak Ridge, Tennessee.

ITEM 1 – Questions Received

1. Instead of using rebar in the concrete for stability, can fiber be used?
No
2. Would you like an ADA mat at the parking lot end of sidewalk?
Yes, parking lot end of sidewalk
3. Is there accessible information for the results of the geo-test done on site for the parking lot?
No

******* Acknowledge receipt of this addendum when you submit your bid *******