

SEBRING CRA REVITALIZATION OF THE WEST CENTER STREET – ROTARY PARK CORRIDOR (REBID) Addendum 2 –

1) QUESTION:

I would like clarification on a question I have regarding this project. I might have misunderstood, but during the CRA board meeting where the vote was approved to send this out for re-bid, it was stated that this project would require a GC. I have looked over the bid document and cannot find any reference to this other than language stating the contractor needs to be licensed in the State of Florida.

ANSWER:

The scope of work would require either a State of Florida Certified General Contractor or Certified Underground Contractor.

2) QUESTION:

Is there any time lines for each side, phasing, or any events to schedule around?

ANSWER:

No, the project will progress in a timely and sequential manner according to the stand alone construction schedule and will not be required to incorporate a schedule of public events as it is nearly impossible to avoid impacting the multitude of events through the life of the project, therefore phasing or shutting down the project for a period of time should not be necessary. However, as per specifications, only one side of the street may be closed at a time.

3) QUESTION:

Existing water meters, are they to be relocated out of sidewalk by contractor or utility owner? Or modify elevation to fit sidewalk elevation?

ANSWER:

Water meters shall remain in their present locations and shall be modified or adjusted to fit the sidewalk elevation.

4) QUESTION:

Are all Type F curbs from Wall Street to Lakeview Drive along West Center to be removed and replaced?

Are the overlays, driveways, and sleeves in the scope? ANSWER:	
Yes	
6)	QUESTION:
Are the	e pavers supplied by the City of Sebring?
ANSW	ER:
Yes, as	s well as the tree grates.
7)	QUESTION:
Is the p	paver type specified in the plans?
ANSW	ER:
No, but it is a standard 80mm. It is the same paver that was installed in Circle Park.	
	ACKNOW! EDCEMENT
ACKNOWLEDGEMENT	

ANSWER: