

September 14, 2018

City of Prattville, Alabama
101 West Main Street
Prattville, Alabama 36067

RE: South Industrial Park Wastewater Improvements
EOS Project No. PV-1605

ADDENDUM No. 2

The changes, modifications and / or additions covered by and set forth in this Addendum No. 2 shall become part of and be incorporated into the Specifications, Contract Documents, and Bid Documents for the above referenced project.

SPECIFICATIONS

SECTION 5 – BID FOR UNIT PRICE CONTRACTS

1. Insert and replace pages 11 and 12 with the attached revisions

SECTION 41 22 13 – HOIST SYSTEMS

1. Replace Section 2.02 – Specific Design Criteria with the following:

“A. South Industrial Park Lift Station Monorail

1. Type: Monorail
2. Trolley: Two speed (10 / 30 fpm) motorized with electric wire rope hoist
3. Rating: 1 ton

This Addendum No. 2 shall be attached to the front of your set of Specifications and made a part of the Specifications and Contract Documents. Acknowledgement of Receipt of Addendum No. 2 shall be returned via facsimile or email to our office.

ENGINEERS OF THE SOUTH, LLC



Greg Thompson, PE

Bidder agrees to perform all the South Industrial Park Wastewater Improvements work described in the specification and shown on the plans, for the following unit prices:

Item	Description	Qty	Unit	Unit Price	Total
1	Mobilization, Bonds, & Insurance	1	LS	\$50,000.00	\$50,000.00
2	Clearing and Grubbing	1	LS		
3	Temporary Erosion Control	1	LS		
4	South Industrial Park Lift Station	1	LS		
5	Abandon Existing Sanitary Sewer Manhole	3	EA		
6	60" Doghouse Manhole – Prop MH: 50	1	LS		
7	48" Manhole (0 – 8' Cut)	3	EA		
8	48" Manhole (8' – 10' Cut)	1	EA		
9	48" Manhole (10' – 12' Cut)	3	EA		
10	48" Manhole (12' – 15' Cut)	1	EA		
11	48" Manhole (15' – 18' Cut)	3	EA		
12	15" PVC Gravity Sewer (0–8' Cut)	540	LF		
13	15" PVC Gravity Sewer (8'–10' Cut)	175	LF		
14	15" PVC Gravity Sewer (10'–12' Cut)	280	LF		
15	15" PVC Gravity Sewer (12'–15' Cut)	100	LF		
16a	10" Ductile Iron Gravity Sewer (15'-18' Cut)	81	LF		
16b	14" Ductile Iron (Restrained Joint) Gravity Sewer (0-8' Cut)	319	LF		
16	14" Ductile Iron Gravity Sewer (0–8' Cut)	280	LF		
17	14" Ductile Iron Gravity Sewer (8'–10' Cut)	5	LF		
18	14" Ductile Iron Gravity Sewer (10'–12' Cut)	5	LF		
19	14" Ductile Iron Gravity Sewer (12'–15' Cut)	140	LF		
20	14" Ductile Iron Gravity Sewer (15'-18' Cut)	417	LF		
21	14" DI MJ x MJ Ex-Tend with MJ Adapters Fused to HDPE Pipe	2	EA		
22	10" DI MJ x MJ Ex-Tend with MJ Adapters Fused to HDPE Pipe	2	EA		

23	Air Release Valve Assembly (Type B) with HDPE Tee	2	EA		
24	10" DR17 HDPE Force Main	6755	LF		
25	10" D17 HDPE Force Main (Horizontal Directional Drill)	590	LF		
26	10" DR17 HDPE Fittings	9	EA		
27	Concrete Anchors	30	EA		
28	Wetlands Jack and Bore Casing Installation with 24" casing	1	LS		
29	Installing Forcemain Through Existing Industrial Parkway Encasements	160	LF		
30	Autauga County Road 4 Jack and Bore Casing Installation from Sta 22+00 to 23+65 with 20" Casing	1	LS		
31	Autauga County Road 4 Jack and Bore Casing Installation from Sta 31+90 to 32+40 with 20" Casing	1	LS		
32	Concrete Pipe Encasement	100	LF		
33	Rip-Rap and Geotextile Fabric	10	SY		
34	Crushed Stone Backfill	2000	TN		
35	Concrete Removal and Replacement	10	SY		
36	Asphalt Removal and Replacement	40	TN		
37	Traffic Control	1	LS		
38	Allowance for Owner / Engineer Selected Items	1	LS	\$75,000.00	\$75,000.00
39	Testing, Start-up, & Restoration of Project Areas	1	LS	\$50,000.00	\$50,000.00

Total Base Bid: _____