



THE CITY OF DAYTONA BEACH  
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451  
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080  
Fax (386) 671-8085

**ADDENDUM NO. 1**

DATE: December 20, 2019

PROJECT: ITB 20233  
PEABODY LOBBY HVAC REPLACEMENT

OPENING DATE: JANUARY 6, 2020 at 2:00 PM

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strike through~~.

1. Condensers will be factory coated for Coast Guard coating protection.
2. Low ambient sensors/controls will be added to the condensers by the manufacture.
3. Attached is a revised bid schedule adding the alternate.
4. Answers to Bidders' written questions:

Q1: Please confirm new ductwork material - ductboard or galvanized steel duct?  
If ductboard please provide specification.

**A1: Ductboard**

Q2: Since this project does not include engineered drawings how will this affect the sub-contractor during permitting and inspections?

**A2: Permit application to include unit information and attachment details.  
Only a final inspection is required.**

5. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach

Kirk Zimmerman, CPPB  
Purchasing Agent

**REVISED BID SCHEDULE  
20233-PEABODY LOBBY HVAC REPLACEMENT**

<b>Ref. No.</b>	<b>Description</b>	<b>Unit of Measure (UOM)</b>	<b>Estimated Qty (Est Qty)</b>	<b>Unit Price</b>	<b>Extended Price</b>
1	Lump Sum project total	LS	1		\$ -
2	Replacement of Ductwork	LF	100		\$ -
	Total Project Amount				\$ -
	Alternate:				
	HVAC Control	EACH	1	\$6,000.00	\$6,000.00