

SimplexGrinnell BE SAFE.

Task # _____
 SR # 40668532

REPORT OF SPRINKLER INSPECTION

Date December 28, 2017

CUSTOMER	KCDC	INSPECTOR NAME	Ted Hatfield
BUILDING / LOCATION	Isabella Towers	SIMPLEXGRINNELL OFFICE	290/Knoxville
STREET	1515 Isabella Circle		1820 Midpark Rd Suite A
CITY / STATE / ZIP/PC	Knoxville, TN 37915		Knoxville, Tenn. 37921
ATTN: Kieth Krowe <i>Mark M Wade</i>		PHONE # 865-675-9945	LICENCE # 536
PHONE # - 865-755-6023 <i>5956</i> Fax		PANEL TYPE - Fire-Lite	

1. GENERAL (To be answered by Customer)

Fire Marshall City Knoxville YES NA NO

- a. Have there been any changes in the occupancy classification, machinery or operations since the last inspection? YES NA NO
- b. Have there been any changes or repairs to the fire protection systems since the last inspection? YES NA NO
- c. If a fire has occurred since the last inspection, have all damaged sprinkler system components been replaced? YES NA NO

If answered "yes" to a, b, or c, list changes in Section 13

- d. Has the piping in all dry systems been checked for proper pitch within the past five years? YES NA NO
 Date last checked _____ (checking is recommended at least every 5 years)
- e. Has the piping in all systems been checked for obstructive materials? YES NA NO
 Date last checked _____ N/A (checking is required at least every 5 years)
- f. Have all fire pumps been tested to their full capacity through the use of hose streams or flow meters within the past 12 months? YES NA NO
- g. Are gravity, surface or pressure tanks protected from freezing? YES NA NO
- h. Standard sprinklers 50 year old or older? QR (20yr) Dry (10yr) >325/163C (5yr) Corrosive env't 5yr YES NA NO
 (Testing or replacement is required for these type sprinklers)
- i. Are any extra high temperature solder sprinklers regularly exposed to temperatures near 300F/149C? YES NA NO
- j. Have gauges been tested, calibrated or replaced in the last 5 years? Date _____ N/A YES NA NO
- k. Alarm valves and associated trim been internally inspected in past 5 years? Date _____ N/A YES NA NO
- l. Check valves internally inspected in the last 5 years? Date _____ N/A YES NA NO
- m. Has the private fire main been flow tested in the last 5 years? Date _____ MAIN DRAIN 12-28-17 YES NA NO
- n. Standpipe 5 years requirements.
 - 1. Dry standpipe hydrostatic test Date _____ YES NA NO
 - 2. Flow test Date _____ YES NA NO
 - 3. Hose hydrostatic test Date _____ YES NA NO
 - 4. Pressure control valve test Date _____ YES NA NO
 - 5. Pressure reducing valve test Date _____ YES NA NO
- o. Have pressure reducing valves been tested at full flow within the past 5 years? YES NA NO
- q. Have master pressure reducing valves been tested at full flow within the past 1 year? YES NA NO
- r. Have the sprinkler systems been extended to all visible areas of the building? YES NA NO
- s. Are the building areas protected by a wet system, heated, including its blind attics and perimeter areas, where accessible? YES NA NO
- t. Are all visible exterior openings protected against the entrance of cold air? YES NA NO

2. CONTROL VALVES

- a. Are all sprinkler system main control valves and all others valves in the appropriate open or closed position? YES NA NO
- b. Are all control valves sealed or supervised in the open position? YES NA NO

Control Valves	# of Valves	Type	Easily Accessible		Signs		Valve Open		Secured? IF YES, HOW?		(Sealed?) (Locked?) (Supvd.?)	Supervision Operational	
			YES	NO	YES	NO	YES	NO	YES	NO		YES	NO
CITY CONNECTION	1	PIV	V		V		V		V		Locked		
BACKFLOW	2	B/Fly	V		V		V		V		Supvd.	V	
PUMP	4	B /Fly OSY	V		V		V		V		Supvd.	V	
SECTIONAL	8	B/Ball	V		V		V		V		Supvd.	V	
SYSTEM													
ALARM LINE													

Location of Control Valves:

Pump Room	
Stairwell @ Lobby	

SimplexGrinnell BE SAFE.

REPORT OF INSPECTION

3. WATER SUPPLY

a. Water supply sources? City:

Gravity Tanks:

Pressure Fire Pump & Tank

Pressure Fire Pump & City

Pressure Fire Pump & Pond

Water Flow Test Results Made During This Inspection

Test Pipe Location	Size Test Pipe	Static Pressure	Flow Pressure	Return Time to Static Pressure	Test Pipe Location	Size Test Pipe	Static Pressure Before	Flow Pressure	Return Time to Static Pressure
		SEE	FLOW	CHART					

4. TANKS, PUMPS FIRE DEPT. CONNECTIONS

- a. Do fire pumps, gravity, surface or pressure tanks appear to be in good external condition?
- b. Are gravity, surface and pressure tanks at the proper pressure and/or water levels
- c. Has the storage tank been internally inspected in the last 5 years Date _____
- d. Are fire dept. connections in satisfactory conditions, coupling free, caps or plugs in place and check valves tight?
- e. Are fire dept. connections visible and accessible?

YES	NA	NO
<input checked="" type="checkbox"/>		
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		

5. WET SYSTEMS

a. No. of systems 8 Make & Model _____ Flow switch per floor _____

b. Are cold weather valves in the appropriate open or closed position?

If closed, has piping been drained?

c. Has the Customer been advised that cold weather valves are not recommended?

d. Have all the antifreeze systems been tested? Date: _____

The antifreeze tests indicated protection to: Note temp & type for each. Example: (-)15F glycol or -15F glycerin

Systems	1)	2)	3)

g. Did alarm valves, waterflow alarm indicators and retards test satisfactorily?

YES	NA	NO
	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>		

6. DRY SYSTEMS

a. No. of systems N/A Make & Model _____

Date last trip tested Partial Full _____

b. Is the air pressure and priming water levels normal?

c. Did the air compressor operate satisfactorily?

d. Air compressor oil check Belts

e. Were auxiliary drains drained during this inspection

No. of Aux. Drains: _____

- Locations 1) _____ 2) _____
- 3) _____ 4) _____

f. Did all quick opening devices operate satisfactorily? Make: _____ Model: _____

g. Did all the dry valves operate satisfactorily during this inspection?

h. Is the dry valve house heated?

i. Do dry valves appear to be protected from freezing?

YES	NA	NO
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	
	<input checked="" type="checkbox"/>	

7. SPECIAL SYSTEMS

a. No. of systems N/A Make & Model N/A

Type _____

b. Were valves tested as required?

c. Did all heat responsive systems operate satisfactorily?

d. Did the supervisory features operate during testing?

e. Has a supplemental test form for this system been completed and provided to the customer? (Please Attach)

Heat Responsive Devices: Type _____ Type of test _____

Auxiliary equipment: No. _____ Type _____

Location _____

Test results _____

YES	NA	NO
	<input checked="" type="checkbox"/>	

8. ALARMS

a. Did the water motors and gong operate during testing?

b. Did the electric alarms operate during testing?

c. Did the supervisory alarms operate during testing?

YES	NA	NO
	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>		
<input checked="" type="checkbox"/>		

Location of Job.

SimplexGrinnell BE SAFE.

REPORT OF INSPECTION

Page 3 of 4

9. SPRINKLER - PIPING

	YES	NA	NO
a. Do sprinklers generally appear to be good external condition? _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Do sprinklers generally appears to be free of corrosion, paint, or loading and visible obstructions? _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Are extra sprinklers and sprinkler wrench available on the premises? _____ (#, size, finish, temp, brand, of spare heads) _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Does the exposed exterior condition of piping, drain valve, check valves, hangers, pressure gauges, open sprinklers and strainers appear to be satisfactory. _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Does the hand hose on sprinkler system appear to be in satisfactory condition? _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Does there appear to be proper clearance between the top of all storage and the sprinkler deflector? _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

10. EXPLANATION OF "NO" ANSWERS (For Sections 1B thru 9):

5-year requirements are due on systems and gauges (12 - Total gauges)
 Hose Valves in 3 stairwells are due a flow test (7 Floors High)

11. THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS. THESE SUGGESTIONS ARE NOT THE RESULT OF AN ENGINEERING SURVEY AND DO NOT REFLECT CONDITIONS ABOVE CEILINGS OR IN CONCEALED SPACE:

Items noted in section #10 per NFPA code

12. ADJUSTMENTS OR CORRECTIONS MADE:

Walk Through
 Main and ITV drains flowed
 All alarms and supervisories checked to alarm panel

13. LIST CHANGES IN THE OCCUPANCY HAZARD OR FIRE PROTECTION EQUIPMENT, AS ADVISED BY THE OWNER IN SECTION 1A:

14. INSPECTION DEFICIENCIES AND SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE CUSTOMER/CUSTOMER REPRESENTATIVE.	YES	NO
If No, explain	<input checked="" type="checkbox"/>	<input type="checkbox"/>

IMPORTANT NOTICE TO CUSTOMER Customer acknowledges and agrees that, in the absence of a Service Agreement between the parties, services hereunder are performed pursuant to the terms and conditions of this Report, agrees that the services have been completed to Customer's satisfaction and that the system is in good working order and repair, unless services performed were of a temporary nature, in which case Customer acknowledges that part of customer's system may have been bypassed or is otherwise inoperable until service can be completed. **CUSTOMER'S ATTENTION IS DIRECTED TO THE LIMITATION OF LIABILITY, WARRANTY, INDEMNITY AND OTHER CONDITIONS AT THE REVERSE SIDE/END OF THIS REPORT.** This Agreement has been drawn up and executed in English at the request of and with the full concurrence of Customer. Ce contract a été rédigé en anglais à la demande et avec l'assentiment du client.

CUSTOMER	X 	Date: Dec 28, 2017	
PRINT NAME	X Linda Jeter		SimplexGrinnell Inspector Signature

Location of Job

DUPLICATE TO _____
 STREET: _____
 CITY, STATE, AND ZIP: _____
 ATTN: _____

SimplexGrinnell BE SAFE.

TERMS AND CONDITIONS

1. **Limitation of Liability; Limitations of Remedy.** It is understood and agreed by the Customer that Company is not an Insurer and that Insurance coverage, if any, shall be obtained by the Customer and that amounts payable to Company hereunder are based upon the value of the services and the scope of liability set forth in this agreement and are unrelated to the value of the Customer's property and the property of others located on the premises. Customer agrees to look exclusively to the Customer's Insurer to recover for injuries or damage in the event of any loss or injury and that Customer releases and waives all right of recovery against Company arising by way of subrogation. Company makes no guaranty or Warranty, including any implied warranty of merchantability or fitness for a particular purpose that equipment or services supplied by Company will detect or avert occurrences or the consequences therefrom that the equipment or service was designed to detect or avert.

It is impractical and extremely difficult to fix the actual damages, if any, which may proximately result from failure on the part of Company to perform any of its obligations under this agreement. Accordingly, Customer agrees that, Company shall be exempt from liability for any loss, damage or injury arising directly or indirectly from occurrences, or the consequences therefrom, which the equipment or service was designed to detect or avert. Should Company be found liable for any loss, damage or injury arising from a failure of the equipment or service in any respect, Company's liability shall be limited to an amount equal to the agreement price (as increased by the price for any additional work) or where the time and material payment term is selected, Customer's time and material payments to Company. Where this agreement covers multiple sites, liability shall be limited to the amount of the payments allocable to the site where the incident occurred. Such sum shall be complete and exclusive. If Customer desires Company to assume greater liability, the parties shall amend this agreement by attaching a rider setting forth the amount of additional liability and the additional amount payable by the Customer for the assumption by Company of such greater liability, provided however that such rider shall in no way be interpreted to hold Company as an Insurer. **IN NO EVENT SHALL COMPANY BE LIABLE FOR ANY DAMAGE, LOSS, INJURY, OR ANY OTHER CLAIM ARISING FROM ANY SERVICING, ALTERATIONS, MODIFICATIONS, CHANGES, OR MOVEMENTS OF THE COVERED SYSTEM(S) OR ANY OF ITS COMPONENT PARTS BY THE CUSTOMER OR ANY THIRD PARTY. COMPANY SHALL NOT BE LIABLE FOR INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OF ANY KIND, INCLUDING BUT NOT LIMITED TO DAMAGES ARISING FROM THE USE, LOSS OF THE USE, PERFORMANCE, OR FAILURE OF THE COVERED SYSTEM(S) TO PERFORM.** The limitations of liability set forth in this agreement shall inure to the benefit of all parents, subsidiaries and affiliates of Company, whether direct or indirect, Company's employees, agents, officers and directors.

2. **Limited Warranty.** COMPANY WARRANTS THAT ITS WORKMANSHIP AND MATERIAL FURNISHED UNDER THIS AGREEMENT WILL BE FREE FROM DEFECTS FOR A PERIOD OF NINETY (90) DAYS FROM THE DATE OF FURNISHING. Where Company provides product or equipment of others, Company will warrant the product or equipment only to the extent warranted by such third party. EXCEPT AS EXPRESSLY SET FORTH HEREIN, COMPANY DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THE SERVICES PERFORMED OR THE PRODUCTS, SYSTEMS OR EQUIPMENT, IF ANY, SUPPORTED HEREUNDER. COMPANY MAKES NO WARRANTY OR REPRESENTATION, AND UNDERTAKES NO OBLIGATION TO ENSURE BY THE SERVICES PERFORMED UNDER THIS AGREEMENT, THAT COMPANY'S PRODUCTS OR THE SYSTEMS OR EQUIPMENT OF THE CUSTOMER WILL CORRECTLY HANDLE THE PROCESSING OF CALENDAR DATES BEFORE OR AFTER DECEMBER 31, 1999.

3. **Indemnity.** Customer agrees to indemnify, hold harmless and defend Company against any and all losses, damages, costs, including expert fees and costs, and expenses including reasonable defense costs, arising from any and all third party claims for personal injury, death, property damage or economic loss, including specifically any damages resulting from the exposure of workers to Hazardous Conditions whether or not Customer pre-notifies Company of the existence of said hazardous conditions, arising in any way from any act or omission of Customer or Company relating in any way to this agreement, including but not limited to the Services under this agreement, whether such claims are based upon contract, warranty, tort (including but not limited to active or passive negligence), strict liability or otherwise. Company reserves the right to select counsel to represent it in any such action.

4. **Hazardous Materials.** Customer represents that, except to the extent that Company has been given written notice of the following hazards prior to the execution of this agreement, to the best of Customer's knowledge there is no:

- "permit confined space," as defined by OSHA, or space in which work must be performed that, because of its construction, location, contents or work activity therein, accumulation of a hazardous gas, vapour, dust or fume or the creation of an oxygen-deficient atmosphere may occur,
- risk of infectious disease,
- need for air monitoring, respiratory protection, or other medical risk,
- asbestos, asbestos-containing material, formaldehyde or other potentially toxic or otherwise hazardous material contained in or on the surface of the floors, walls, ceilings, insulation or other structural components of the area of any building where work is required to be performed under this agreement.

All of the above are hereinafter referred to as "Hazardous Conditions". Company shall have the right to rely on the representations listed above. If hazardous conditions are encountered by Company during the course of Company's work, the discovery of such conditions shall constitute an event beyond Company's control and Company shall have no obligation to further perform in the area where the hazardous conditions exist until the area has been made safe by Customer as certified in writing by an independent testing agency, and Customer shall pay disruption expenses and re-mobilization expenses as determined by Company. This agreement does not provide for the cost of capture, containment or disposal of any hazardous waste materials, or hazardous materials, encountered in any of the Covered System(s) and/or during performance of the Services. Said materials shall at all times remain the responsibility and property of Customer. Company shall not be responsible for the testing, removal or disposal of such hazardous materials.

5. **Equipment Disconnections.** This represents Company's notice to you that the system(s)/device(s) listed on the face of this agreement as temporarily or permanently disconnected are no longer in service and, thus, cannot detect, perform and/or report occurrences or transmit signals.

6. **General.** Unless otherwise specified, work shall be done between the hours of 8:00 AM and 5:00 PM, exclusive of Saturdays, Sundays and Company holidays. All work is subject to review and rebidding in accordance with the terms and conditions of Customer's agreement/contract with Company, if one is in effect. Company shall not be responsible for failure to render services due to causes beyond its control, including but not limited to material shortages, work stoppages, fires, civil disobedience or unrest, severe weather, fire or any other cause beyond the control of Company. Customer is aware that the Limitation of Liability and other provisions set forth in any existing agreement/contract, if one is in effect, or set forth above, apply to services performed and materials supplied. The terms of this agreement shall govern notwithstanding any inconsistent or additional terms and conditions in any purchase order or other document submitted by Customer.

