



## ADDENDUM NO. 1

Issue Date: November 9, 2023

Project Name: Sporting Clays Facility Improvements  
IRC - 1847

Bid Number: 2024016

Bid Opening Date: **November 29, 2023**

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.**

### Questions and Answers

1. Are there any requirements or contact to access the site?  
**Bidders can call the County Shooting Range at (772) 226-3091 Thursday through Monday between the hours of 9:00 AM – 5:00 PM to schedule a visit with Jerry Seldes. Range is closed Tuesday and Wednesday. Bidders are reminded to not ask questions to staff members of the Range and all questions need to be submitted to the Purchasing Division for answers through a published Addendum.**
2. Please verify who is paying for the testing lab?  
**The Contractor needs to retain a geotechnical testing company and provide testing results to the County. The County also retains a testing company for verification testing.**
3. There are not bid items for Clearing, Excavation, and Grading. Would you like to add line items, or do we need to include these items in the Base Group 11 bid item?  
**The Bid Schedule line item 110-2-2, Selective Clearing & Grubbing, areas with trees to remain is where the Contractor is to include the cost. The project area is partially within a “wetlands environment”. Under the FDOT specification for this item Contractor is to remove and dispose vegetation, obstructions, and fill any holes or voids. The County expects the base material for the paths to start as close to existing ground as possible.**
4. Could you please verify that the unit for the Base Group Item for shell is Cubic Yards or Tons? It is shown in Cubic Yards. Just wanted to confirm.

**The bid Pay Item 285-711 unit is in Cubic Yards (in place). The County is paying for a finished template of material 12" thick in place. Screened shell could have an approximate weight of 1.5 tons/cubic yard for trucking purposes.**

5. Are the walking/cart paths on the sporting courses required to be created with the Base Group 11 shell or could it be screened shell?

**The Pay Item listed is referring to a FDOT number but the language on the Bid Form and also on Plan Sheet 3 of 7 is specifying Screened Shell. The screened shell must be used to satisfy the state agency permits for the project.**

6. The cubic yards listed for the shell is 3,100 – in the case that we end up going needing more shell than that, will a change order be allowed and paid.

**The bid Pay Item 285-711 unit is in Cubic Yards (in place). The County is paying for a finished template of material 12" thick in place. Screened shell could have an approximate weight of 1.5 tons/cubic yard for trucking purposes.**