

ADDENDUM NUMBER ONE
RFQ FOR PROFESSIONAL SERVICES FOR WOOD RECYCLE CENTER FACILITY
FOR THE CITY OF CHATTANOOGA, TENNESSEE
Contract Number C-17-017-101

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

I. Q&A

Q1: In regards to section 3.4, "City Supplied Services". Will the city be needing civil engineering plans from the consultant for the 10' limit around the building, including sidewalk layout, grading, drainage, and utility connections?

A1: The City will provide the Consultant with finished grade elevations to base the building design of the FFE. The consultant team shall be responsible for the design of the building pad to a limit of 10 feet from the exterior walls of the building and shall include the size and location of all utility services and building drainage lines to the 10 feet limit. From that point the City will design all site drainage, grading, sidewalk layout, planting, etc. The consultant team shall also be responsible for providing the design of all domestic water backflow prevention devices including hot boxes, if placed exterior to the building, and all Fire Protection service requirements as required by code.

January 18, 2017

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works