

ADDENDUM NO. 1

BID NO: 304558

DATE OF BID OPENING: Jan.31, 2017

TIME: 2:00 PM

DEPARTMENT: Waste Resources

COMMODITY: Digester Covers

Clarification of Specifications

1-Bidder shall include an estimated time of performance to complete the work in their bid and any temperature limitations on their product.

2- Specifications Section B.1. Detailed scope of work.
Since handrails are in place, omit the sentence "Set up safety tie-off system"

3- Specification Section B-9. Add "The silicone topcoat shall extend 6" over the seam where the outer vertical wall meets the horizontal roof metal flashing. The seam shall be sealed with silicone caulk or other approved method to prevent water from penetrating during the 10 year warranty period."

4- Contractor shall notify the Control Room when on-site and when working on the Digester.

(SIGNED) _____

COMPANY: _____

PLEASE SIGN ONE (1) COPY OF ADDENDUM AND RETURN TO THE PURCHASING DEPARTMENT (ghipp@chattanooga.gov or fax to 423-643-7244 or mail to Purchasing (Attn: Geoffrey Hipp), 101 E. 11th St., Chattanooga, TN 37402). RETAIN A COPY FOR YOUR FILES.