



**City of Tallmadge
Department of Public Service
2020 Concrete Maintenance & Repair**

Addendum No. 4 to Bidding Documents

February 10, 2020

The City failed to specify what the reinforcement should be in the K Item 451 - 8" Reinforced Concrete Pavement on the alternate bid for the Fire Station parking lot.

The reinforcement for this concrete shall be 6 X 6 W4/W4 4/4 58# Road Mesh.

I acknowledge the receipt of Addendum No. 4:

Company Name

Officer's Name

Officer's Signature

Date

THIS COMPLETED FORM MUST BE SUBMITTED WITH BID PROPOSAL