

City of Waycross  
Purchasing Department  
Addendum #1  
Bid # 21-10  
Water Tank Inspections and Washouts  
January 4, 2021

- 1) Can commercial divers be used to complete interior cleaning & inspection services in accordance with AWWA C652 & FAC Rule 62-555.350? ***No Commercial Divers.***
- 2) How much and what type of sediment is to be expected within each individual tank? ***The reports for each tank that was included in the bid package is the only information that we have available.***
- 3) If the amount of sediment accumulated within any tank exceeds the amount anticipated, will additional charges be negotiated? ***No.***
- 4) Can the sediment removed from inside the tank during the cleaning process be disposed of on-site? ***No, must be taken to a landfill.***
- 5) Does this contract include any structural repairs or coating repairs, other than vandalism cover-ups? ***No.***

---

*Name of Company*

*Authorized Signature*