



ADDENDUM NO. 1

Date: January 26, 2022

To: All Interested Parties

From: Litsy C. Pittser, Procurement Specialist
Village of Palmetto Bay
9705 E Hibiscus Street
Palmetto Bay, Florida 33157

Re: Invitation to Bid No. 2022-11-004
Sub-Basin 61 Paving and Drainage Improvements

This Addendum forms part of the Invitation to Bid (ITB) Package advertised on January 6th, 2022, and with a bid opening date of January 27th, 2022, with any amendments and/or additions noted below.

Question: Bid Item PM-1 is Outfall Pipe Rehabilitation. The bid item description below has several items that need to be included. However, I was not able to confirm if the manatee grate is in existence or if it is in good condition. Please provide pipe size, type (RCP, Plastic CMG, etc.) and confirmation of the manatee grate condition. I tried to find out via a site visit, but it was not possible to access due to the easement being on private property.

Response: The pipe size & material is on the plans. The manatee grates would be for the corresponding pipe size. We tried reaching out to the Consultant to give us a report on the condition of the manatee grate, but we are still waiting for a call back. For the purpose to submit the bid, we suggest for you to assume that a replacement would be needed.

Thank you,

A handwritten signature in blue ink, appearing to read "Litsy C. Pittser", is written over a large, stylized blue scribble.

Litsy C. Pittser
Procurement Specialist

ACKNOWLEDGEMENT OF ADDENDUM SOLICITATION



Amendment/Modification No: 1

Amendment of ITB No: 2022-11-004

Title: Sub-Basin 61 Paving and Drainage Improvements

Name of Contractor _____

Date Addendum Received _____

Total Pages of Addendum including Acknowledgement 2

Print Name _____

Signature _____

All other terms and conditions stipulated in the original Village of Palmetto Bay Invitation to Bid shall remain in force. All addenda created will be incorporated into the final contract and must be acknowledged in all bids. This acknowledgement form must be included in the response and failure to sign and submit this form may result in rejection of your bid.