

Addendum #5

East Lake Community Center Renovations

CONTRACT NO. Y-17-005

Bid schedule per Addendum #5

Pre-Bid Meeting January 9th, 2020 at 10:00am

Last Day for Questions January 17th, 2020

Bid Opening January 30th, 2020 at 2:00 pm

Questions Received via Email

1. Request to postpone bids by 1 week.
 - a. City of Chattanooga has postponed the bid date until 1/30/2020. This change is reflected in the schedule above.
2. Is there a Buy America clause or AIS document requiring this to be domestic steel only?
 - a. No, there is no domestic steel requirement for this project.
3. It is not clear what kind of roofing to use. If the metal roof spec 74113 is to be used then we can't supply the roof. Will the metal building roofing match the metal panel roofing?
 - a. 74113 is intended to be only for the lower roofs over the conventional-framed structure. The metal building is intended to use a metal panel provided by the PEMB manufacturer. The two different roofs are not intended to match.
4. Will the metal wall panels on the metal building portion be the same as the panels on the other additions/existing building?
 - a. Yes, all metal wall panels are intended to be the same.
5. What are the weights for the suspended basketball goals?
 - a. We can only provide an approximation at this point based on the product specified as the Basis of Design. Actual loads will depend on the actual goal/backboard units and their supporting structure proposed by the successful bidder.
6. Please provide collateral load for the metal building.
 - a. 8 psf per the structural engineer.
7. Will the metal building manufacturer be required to hold AISC Certification?
 - a. Yes, per Specification 133419 Para. 1.5-A-1.

End of Addendum #5