



ADDENDUM NO. [1]

Issue Date: March 19, 2021

Project Name: Sandridge Golf Club Dunes Course Irrigation Pump Station
Wet Well

Bid Number: 2021032

Bid Opening Date: March 30, 2021

This addendum is being released to answer questions received to date and modify bid documents.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Modifications to Bid Documents:

- Contractor is responsible for all de-watering. Golf Maintenance will assist in the drawdown by running the irrigation system through the old pump station until water has reached the allowable level of the intake.
- Intake Screen will be purchased through Sandridge Golf Club. Contractor responsible for installation.
- Contractor shall ensure a minimum of 2'-0" from the bottom of the lake intake screen box. **Not from the bottom of the intake flume**, as it states in the specifications.

Attachments:

Updated Bid Form

Questions and Answers

1. Can the pond at the Wet Well site be used as a source of jet water to install the wellpoints?
No.
2. What is the elevation for the lake?
24.66'.

Bid Form

Sandridge Golf Club Dunes Course Irrigation Pump Station Wet Well

Bid #: 2021032
 Bid Opening Date and Time: March 30, 2021 2:00 P.M.
 Bid Opening Location: Purchasing Division
 1800 27th Street
 Vero Beach, FL 32960

The following addenda are hereby acknowledged:

Addendum Number	Date

In accordance with all terms, conditions, specifications, and requirements, the Bidder offers the following:

WET WELL SYSTEM	LUMP SUM TOTAL
1. Mobilization	\$
2. Pump Station Wet Well	\$
3. Intake Pipe	\$
4. Intake Screen (installation only)	\$
5. Fertigation Containment Area (Wall and Slab)	\$
6. Permit fees (fixed price)	\$ 888.47
TOTAL COMPLETE PUMP STATION SYSTEM	\$

Total Bid Price in Words

Project completion time after receipt of "Notice to Proceed": _____ DAYS