



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. 2

Posting Date: Thursday, February 10, 2023

Solicitation Number: 2223-26VS

Description: Myrtle Beach High (MBH) School Mechanical Renovations

ADDENDA: Addenda shall be issued prior to the bid opening date and time for the purposes of modifying or interpreting the Contract Documents through additions, deletions, clarifications or corrections. No addendum shall be issued later than four (4) days prior to the bid opening date except to a) withdraw the Invitation for Bids, or b) to postpone the bid opening date and time. When an addendum is issued for the purposes of postponing the bid opening date and time, the addendum shall establish the new bid opening date and time no earlier than five (5) days after the addendum issue date. Addenda shall be posted on the on-line bidding source(s) stated in the Invitation for Bids. A Bidder shall acknowledge receipt of all addenda issued by identifying the addendum number and the date of issuance with the Bidder's initials in the spaces provided on the Official Bid Form or the bid shall be found non-responsive in accordance with the District's Procurement Code. If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

INTERPRETATIONS AND CLARIFICATIONS: Requests for additional information or questions regarding error, omission or clarification of any portion of the Bid Documents or the Contract Documents or any addendum, shall be submitted in writing to the District Bid Contact Person stated in the Invitation for Bids by e-mail or facsimile no later than five (5) days prior to the bid opening date and time unless an earlier date is stated on the Invitation for Bids or as may be amended. Any interpretations, corrections, or changes to the Bid Documents or the Contract Documents made in any other manner than by a written addendum shall not be binding, and Bidders shall not rely upon them. Any information given a prospective Bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an addendum to the solicitation, if that information is necessary for submitting offers of if the lack of it would be prejudicial to other prospective bidders. See clause entitled "Bidder Representations." We will not identify you in our answer to your question. The District seeks to permit maximum practicable competition. Bidders are urged to advise the Procurement Specialist – as soon as possible – regarding any aspect of this procurement, including any aspect of the solicitation that unnecessarily or inappropriately limits full and open competition.

-
1. Reference is made to sheet ME-207, Electrical Disconnect Schedule:
 - *Change electrical requirements for Packaged Rooftop Heat Pump # 10 to ¾" conduit with 3 #8 and 1 #12 ground. Provide new ¾" conduit and wire. Remove existing 30 Amp breaker serving existing unit and provide new ¾" conduit and wire. Provide new 35 Amp breaker in existing panel and fuse 60A disconnect to manufacturer's MOCP of 35 Amps. Match manufacturer for new 35 Amp HACR breakers. Coordinate breaker and fuse sizes with units provided by the mechanical contractor.*
 2. Reference is made to specification section 15846, A, Condenser Water Piping. Add the following:
 - *"Type L" Copper piping and Viega "Pro-Press" fitting are acceptable in lieu of specified PPE piping for all condenser water piping 2" and smaller. The ½" fiberglass insulation specified to cover the PPE plastic piping is not required on the copper condenser water piping.*

3. Reference is made to specification 15040, 2.12 – Guarantee, Section A.
 - *Provide a manufacturer's 5-year parts and labor warranty for entire unit for all Packaged Heat Pumps.*