



# St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

---

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • [www.sjrwmd.com](http://www.sjrwmd.com)

DATE: October 10, 2023  
TO: Prospective Respondents  
FROM: Amy Lucey, Procurement Specialist  
SUBJECT: Addendum #1 to Invitation for Bid, # 39270, Limerock Purchase and Delivery to Lake Apopka North Shore.

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents.

Q1: On page 37 of the IFB states that you are asking for **stabilized road base limerock**, but the specifications chart shows DOT Road Base Limerock. Stabilized road base limerock is 1-1/2" to fines in size and is much more expensive. DOT Road base is 3-1/2" to fines in size and is what you have purchased in the past. Do you want the DOT Road Base as you have purchased in the past?

A1: Yes, we want the FDOT road base.

**NOTE:** The Bid Due Date remains **2:00 p.m. Thursday, October 26, 2023**

Please acknowledge receipt of this Addendum on the Bid Form provided in the proposal package.

If you have any questions, please e-mail me at [alucey@sjrwmd.com](mailto:alucey@sjrwmd.com).

