



Board of County Commissioners • Escambia County, Florida

Paul R. Nobles/Purchasing Manager
Office of Purchasing

February 6, 2019

To: All Known Prospective Bidders

ADDENDUM NUMBER 1:

Re: PD 18-19.024, Escambia County Supervisor of Elections Warehouse Modification

All:

Your firm recently received an Invitation to Bid for the above-mentioned specification.

This Addendum Number 1 provides for:

1. **Contractor and Sub-Contractor Building Walk Through**

February 8, 2019, 1:00 p.m. CDT, 3201 West Navy Boulevard, Pensacola, FL 32505.
This will be the only date available after the pre-solicitation meeting for access to the building.

2. **Response to RFI's**

Provide Specifications for the Toilet Partitions.

Response – see attached **SECTION 10210 - TOILET COMPARTMENTS**

This Addendum Number 1 is furnished to all known prospective bidders. Please sign and return one copy of this Addendum, with original signature, with your bid as an acknowledgement of your having received same. You may photo copy this form for your records.

Sincerely,

Paul R. Nobles
Purchasing Manager

A handwritten signature in black ink, appearing to read "Paul R. Nobles", is written over a horizontal line.

Acknowledgement of Receipt of Addendum 1:

SIGNED: _____

COMPANY: _____

213 South Palafox Place, 2nd Floor • Pensacola, Florida 32502
P.O. Box 1591 • Pensacola, Florida 32591-1591
850.595.4980 • www.myescambia.com



SECTION 10210 - TOILET COMPARTMENTS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Phenolic-core toilet compartments configured as toilet enclosures.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For toilet compartments. Include plans, elevations, sections, details, and attachments to other work.
- C. Samples for each exposed product and for each color and texture specified.

1.3 CLOSEOUT SUBMITTALS

- A. Maintenance data.

1.4 QUALITY ASSURANCE

- A. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84, or another standard acceptable to authorities having jurisdiction, by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 1. Flame-Spread Index: 25 or less.
 2. Smoke-Developed Index: 450 or less.
- B. Regulatory Requirements: Comply with applicable provisions in the U.S. Architectural & Transportation Barriers Compliance Board's "Americans with Disabilities Act (ADA) and Architectural Barriers Act (ABA) Accessibility Guidelines for Buildings and Facilities" and ICC/ANSI A117.1 for toilet compartments designated as accessible.

PART 2 - PRODUCTS

2.1 PHENOLIC-CORE UNITS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. Ampco, Inc.

2. Bobrick Washroom Equipment, Inc.
3. Bradley Corporation; Mills Partitions.
4. General Partitions Mfg. Corp.
5. Metpar Corp.
6. Rockville Partitions Incorporated.

- B. Toilet-Enclosure Style: Floor anchored and overhead braced.
- C. Door, Panel, Screen, and Pilaster Construction: Solid phenolic-core panel material with melamine facing on both sides fused to substrate during panel manufacture (not separately laminated), and with eased and polished edges and no-sightline system. Provide minimum 3/4-inch- (19-mm-) thick doors and pilasters and minimum 1/2-inch- (13-mm-) thick panels.
- D. Pilaster Shoes and Sleeves (Caps): Fabricated from stainless-steel sheet, not less than 3 inches (76 mm) high, finished to match hardware.
- E. Urinal-Screen Post: Manufacturer's standard post design of monolithic phenolic urinal screen cut out at bottom to form a post; with shoe and sleeve (cap) matching that on the pilaster.
- F. Brackets (Fittings):
 1. Stirrup Type: Ear or U-brackets, stainless steel.
 2. Full-Height (Continuous) Type: Manufacturer's standard design; stainless steel.
- G. Phenolic-Panel Finish: Facing sheet of one color and pattern in each room.
 1. Color and Pattern: As selected by Architect from manufacturer's full range, with manufacturer's standard through-color core matching face sheet.

2.2 ACCESSORIES

- A. Hardware and Accessories: Manufacturer's standard design, heavy-duty operating hardware and accessories.
 1. Material: Stainless steel.
 2. Hinges: Manufacturer's standard continuous, cam type that swings to a closed or partially open position.
 3. Latch and Keeper: Manufacturer's standard surface-mounted latch unit designed for emergency access and with combination rubber-faced door strike and keeper. Provide units that comply with regulatory requirements for accessibility at compartments designated as accessible.
 4. Coat Hook: Manufacturer's standard combination hook and rubber-tipped bumper, sized to prevent in-swinging door from hitting compartment-mounted accessories.
 5. Door Bumper: Manufacturer's standard rubber-tipped bumper at out-swinging doors.
 6. Door Pull: Manufacturer's standard unit at out-swinging doors that complies with regulatory requirements for accessibility. Provide units on both sides of doors at compartments designated as accessible.
- B. Overhead Bracing: Manufacturer's standard continuous, extruded-aluminum head rail with anti-grip profile and in manufacturer's standard finish.

- C. Anchorages and Fasteners: Manufacturer's standard exposed fasteners of stainless steel or chrome-plated steel or brass, finished to match the items they are securing, with theft-resistant-type heads. Provide sex-type bolts for through-bolt applications. For concealed anchors, use stainless steel, hot-dip galvanized steel, or other rust-resistant, protective-coated steel.

2.3 FABRICATION

- A. Floor-Anchored and Overhead Braced Units: Provide manufacturer's standard corrosion-resistant anchoring assemblies with leveling adjustment at tops and bottoms of pilasters. Provide shoes and sleeves (caps) at pilasters to conceal anchorage.
- B. Door Size and Swings: Unless otherwise indicated, provide 24-inch- (610-mm-) wide, in-swinging doors for standard toilet compartments and 36-inch- (914-mm-) wide, out-swinging doors with a minimum 32-inch- (813-mm-) wide, clear opening for compartments designated as accessible.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Comply with manufacturer's written installation instructions. Install units rigid, straight, level, and plumb. Secure units in position with manufacturer's recommended anchoring devices.
- B. Clearances: Maximum 1/2 inch (13 mm) between pilasters and panels; 1 inch (25 mm) between panels and walls.
- C. Stirrup Brackets: Secure panels to walls and to pilasters with no fewer than three brackets attached at midpoint and near top and bottom of panel. Locate wall brackets so holes for wall anchors occur in masonry or tile joints. Align brackets at pilasters with brackets at walls.

3.2 ADJUSTING

- A. Hardware Adjustment: Adjust and lubricate hardware according to hardware manufacturer's written instructions for proper operation. Set hinges on in-swinging doors to hold doors open approximately 30 degrees from closed position when unlatched. Set hinges on out-swinging doors to return doors to fully closed position.

END OF SECTION 10210