

REGULATORY COMPLIANCE SERVICES, INC.

13400 Sutton Park Drive South, Suite 1204 Jacksonville, Florida 32224

229-293-9990

trey@rcsenvironmental.net

SUMMARY FINDINGS ASBESTOS SURVEY OLD PIERCE COUNTY ADMINISTRATION BUILDING JUNE 1, 2016

MATERIAL	QUANTITY	LOCATION
FLOOR TILE & MASTIC	14,650 square feet	Rear sections up and downstairs
2X2 ACOUSTICAL CEILING TILES	7000 square feet	North and South sections of rear building area both floors
HVAC BLACK PIPE INSULATION	200 linear feet	Downstairs mechanical room
CEILING TEXTURE	3400 square feet	Sanctuary Ceiling
2X4 ACOUSTICAL CEILING TILES	12,400 square feet	Rear sections Center rooms up and downstairs
WALLBOARD JOINT COMPOUND	8850 square feet	Rear sections up and downstairs
BUILT UP ROOFING (LAYER 2 OF 4)	1200 square feet	Flat roof connecting buildings east of Sanctuary

NOTES:

1. The majority of the floor tile and bound mastic is under carpet.
2. The ceiling texture in the Sanctuary is maximum twenty-five feet (25') above floor level.
3. The wallboard joint compound must be removed as a unit with the bound sheetrock.
4. The built up roofing can be handled by the demolition contractor as non-friable material.



June 1, 2016

Regulatory Compliance Services, Inc.
13400 Sutton Park Dr. S, Ste 1204
Jacksonville, FL 62224

CLIENT PROJECT: Pierce Co Admin - Old Church Building; 052516A
CEI LAB CODE: B16-4179

Dear Customer:

Enclosed are asbestos analysis results for PLM Bulk samples received at our laboratory on May 27, 2016. The samples were analyzed for asbestos using polarizing light microscopy (PLM) per the EPA 600 Method.

Sample results containing >1% asbestos are considered asbestos-containing materials (ACMs) per EPA regulatory requirements. The detection limit for the EPA 600 Method is <1% asbestos by weight as determined by visual estimation.

Thank you for your business and we look forward to continuing good relations. If you have any questions, please feel free to call our office at 919-481-1413.

Kind Regards,

A handwritten signature in black ink, appearing to read "Tianbao Bai".

Tianbao Bai, Ph.D., CIH
Laboratory Director





ASBESTOS ANALYTICAL REPORT
By: Polarized Light Microscopy

Prepared for

Regulatory Compliance Services, Inc.

CLIENT PROJECT: Pierce Co Admin - Old Church Building; 052516A

CEI LAB CODE: B16-4179

TEST METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

REPORT DATE: 06/01/16

TOTAL SAMPLES ANALYZED: 13

SAMPLES >1% ASBESTOS: 8

TEL: 866-481-1412

www.ceilabs.com



Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: Pierce Co Admin - Old Church Building; **CEI LAB CODE:** B16-4179
052516A

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
A-100		B174936A	Cream	Floor Tile	Chrysotile 3%
		B174936B	Black	Mastic	Chrysotile 5%
A-101		B174937A		Sample Not Analyzed per COC	
		B174937B		Sample Not Analyzed per COC	
A-102		B174938A		Sample Not Analyzed per COC	
		B174938B		Sample Not Analyzed per COC	
A-103		B174939A		Sample Not Analyzed per COC	
		B174939B		Sample Not Analyzed per COC	
B-100		B174940	Tan	Ceiling Tile	Chrysotile 2%
B-101		B174941		Sample Not Analyzed per COC	
B-102		B174942		Sample Not Analyzed per COC	
B-103		B174943		Sample Not Analyzed per COC	
C-100		B174944	Black	Hvac Insulation	Chrysotile 15%
C-101		B174945		Sample Not Analyzed per COC	
D-100		B174946	Off-white	Tetxure Sactuary	Chrysotile 5%
D-101		B174947		Sample Not Analyzed per COC	
E-100		B174948	Tan	Ceiling Tile	Chrysotile 2%
E-101		B174949		Sample Not Analyzed per COC	
E-102		B174950		Sample Not Analyzed per COC	
E-103		B174951		Sample Not Analyzed per COC	
F-100		B174952	Tan	Celotex Above	None Detected
F-101		B174953	Tan	Celotex Above	None Detected
G-100		B174954	Off-white	Wallboard Joint Compound	Chrysotile 3%
G-101		B174955		Sample Not Analyzed per COC	
G-102		B174956		Sample Not Analyzed per COC	
G-103		B174957		Sample Not Analyzed per COC	
H-100		B174958	White, Tan	Window Glazing	None Detected
H-101		B174959	White	Window Glazing	None Detected
I-100		B174960	Black	Asphalt Shingle	None Detected
I-101		B174961	Black	Asphalt Shingle	None Detected
J-100	Layer 1	B174962	Black	Built-Up Roofing	None Detected



Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: Pierce Co Admin - Old Church Building;
052516A

CEI LAB CODE: B16-4179

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
	Layer 2	B174962	White,Off-white	Built-up Roofing- Residue/ Coating	Chrysotile 5%
J-101		B174963		Sample Not Analyzed per COC	



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Regulatory Compliance Services, Inc.
 13400 Sutton Park Dr. S, Ste 1204
 Jacksonville, FL 62224

CEI Lab Code: B16-4179
Date Received: 05-27-16
Date Analyzed: 06-01-16
Date Reported: 06-01-16

Project: Pierce Co Admin - Old Church Building; 052516A

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS		ASBESTOS %	
			Fibrous	Non-Fibrous		
A-100 B174936A	Floor Tile	Heterogeneous	22%	Binder	3% Chrysotile	
		Cream Non-fibrous Bound	75%	Vinyl		
B174936B	Mastic	Heterogeneous Black Fibrous Bound	95%	Tar	5% Chrysotile	
A-101 B174937A	Sample Not Analyzed per COC					
B174937B	Sample Not Analyzed per COC					
A-102 B174938A	Sample Not Analyzed per COC					
B174938B	Sample Not Analyzed per COC					
A-103 B174939A	Sample Not Analyzed per COC					
B174939B	Sample Not Analyzed per COC					
B-100 B174940	Ceiling Tile	Heterogeneous	45%	Fiberglass	38%	2% Chrysotile
		Tan Fibrous Bound	15%	Cellulose		
B-101 B174941	Sample Not Analyzed per COC					
B-102 B174942	Sample Not Analyzed per COC					
B-103 B174943	Sample Not Analyzed per COC					



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Regulatory Compliance Services, Inc.
 13400 Sutton Park Dr. S, Ste 1204
 Jacksonville, FL 62224

CEI Lab Code: B16-4179
Date Received: 05-27-16
Date Analyzed: 06-01-16
Date Reported: 06-01-16

Project: Pierce Co Admin - Old Church Building; 052516A

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
C-100 B174944	Hvac Insulation	Heterogeneous Black Fibrous Bound	85%		Binder		15% Chrysotile
C-101 B174945	Sample Not Analyzed per COC						
D-100 B174946	Tetxure Sactuary	Heterogeneous Off-white Fibrous Bound	60%		Binder		5% Chrysotile
D-101 B174947	Sample Not Analyzed per COC						
E-100 B174948	Ceiling Tile	Heterogeneous Tan Fibrous Bound	15%	Cellulose	48%	Binder	2% Chrysotile
E-101 B174949	Sample Not Analyzed per COC						
E-102 B174950	Sample Not Analyzed per COC						
E-103 B174951	Sample Not Analyzed per COC						
F-100 B174952	Celotex Above	Heterogeneous Tan Fibrous Bound	95%	Cellulose	5%	Binder	None Detected
F-101 B174953	Celotex Above	Heterogeneous Tan Fibrous Bound	95%	Cellulose	5%	Binder	None Detected



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Regulatory Compliance Services, Inc.
 13400 Sutton Park Dr. S, Ste 1204
 Jacksonville, FL 62224

CEI Lab Code: B16-4179
Date Received: 05-27-16
Date Analyzed: 06-01-16
Date Reported: 06-01-16

Project: Pierce Co Admin - Old Church Building; 052516A

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
G-100 B174954	Wallboard Joint Compound	Heterogeneous Off-white Fibrous Bound	62%	Binder	35%	Calc Carb	3% Chrysotile
G-101 B174955	Sample Not Analyzed per COC						
G-102 B174956	Sample Not Analyzed per COC						
G-103 B174957	Sample Not Analyzed per COC						
H-100 B174958	Window Glazing	Heterogeneous White, Tan Non-fibrous Bound	55%	Binder	10%	Paint	None Detected
H-101 B174959	Window Glazing	Heterogeneous White Non-fibrous Bound	55%	Binder	10%	Paint	None Detected
I-100 B174960	Asphalt Shingle	Heterogeneous Black Fibrous Bound	35%	Fiberglass	40%	Tar	None Detected
I-101 B174961	Asphalt Shingle	Heterogeneous Black Fibrous Bound	35%	Fiberglass	40%	Tar	None Detected
J-100 Layer 1 B174962	Built-Up Roofing	Heterogeneous Black Fibrous Bound	25%	Cellulose	75%	Tar	None Detected



ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Regulatory Compliance Services, Inc.
13400 Sutton Park Dr. S, Ste 1204
Jacksonville, FL 62224

CEI Lab Code: B16-4179
Date Received: 05-27-16
Date Analyzed: 06-01-16
Date Reported: 06-01-16

Project: Pierce Co Admin - Old Church Building; 052516A

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS		ASBESTOS %
			Fibrous	Non-Fibrous	
Layer 2 B174962	Built-up Roofing- Residue/ Coating	Heterogeneous White, Off-white Fibrous Bound	95%	Binder	5% Chrysotile
J-101 B174963	Sample Not Analyzed per COC				



107 New Edition Court, Cary, NC 27511
 Tel: 866-481-1412; Fax: 919-481-1442

ASBESTOS CHAIN OF CUSTODY

LAB USE ONLY:
CEI Lab Code: B16-4179 (28)
CEI Lab I.D. Range: B174936-B174963

COMPANY INFORMATION	PROJECT INFORMATION
CEI CLIENT #:	Job Contact: Trey Fausett
Company: REGULATORY COMPLIANCE SERVICES, INC.	Email / Tel: trey@rcsenvironmental.net/ 229.563.2932
Address: 13400 Sutton Park Drive, South, Suite 1204 Jacksonville, Florida 32224	Project Name: Pierce Co Admin - Old Church Building
Email: barbie@rcsenvironmental.net	Project ID# 052516A
Tel: 229.293.9990 Fax: 855.301.8081	PO #:
STATE SAMPLES COLLECTED IN: Georgia	

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES.

ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR	8 HR	24 HR	2 DAY	3 DAY	5 DAY
PLM BULK	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT (400)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT (1000)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM GRAV w POINT COUNT	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM BULK	CARB 435	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PCM AIR	NIOSH 7400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	EPA AHERA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	NIOSH 7402	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	ISO 10312	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	ASTM 6281-09	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM BULK	CHATFIELD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST WIPE	ASTM D6480-05	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST MICROVAC	ASTM D5755-09	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM SOIL	ASTM D7521-13	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM VERMICULITE	CINCINNATI METHOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS / SPECIAL INSTRUCTIONS: Positive Stop all "101" and higher samples		<input checked="" type="checkbox"/> Accept Samples
		<input type="checkbox"/> Reject Samples
Relinquished By: <i>Trey Fausett</i>	Date/Time: <i>5/26/16</i>	Received By: <i>[Signature]</i>
		Date/Time: <i>5-27-16 9:20am</i>

Samples will be disposed of 30 days after analysis

TRACKING # 8010 4611 8623

ASBESTOS SAMPLING FORM



COMPANY CONTACT INFORMATION	
Company: REGULATORY COMPLIANCE SERVICES, INC.	Job Contact: Trey Fausett
Project Name: Pierce Co Admin - Old Church Building	trey@rcsenvironmental.net
Project ID #: 052516A	Tel: 229.563.2932

SAMPLE ID#	DESCRIPTION / LOCATION	VOLUME/ AREA	TEST			
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
A-100	12x2 FTM - Down - N	14650	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
A-101	✓ ✓ - ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
A-102	12x12 FTM - UP - N		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
A-103	✓ ✓ - ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
B-100	2x2 ACT DOWN - N	7000	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
B-101	✓ ✓ ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
B-102	2x2 ACT UP - N		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
B-103	✓ ✓ ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
C-100	HVAC INSULATION BLACK-UP 160LF		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
C-101	✓ ✓ ✓ - Down		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
D-100	TEXTURE SACTURY - E	3480	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
D-101	✓ ✓ ✓ - W		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
E-100	2x4 ACT - DOWN - N	12,400	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
E-101	✓ ✓ ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
E-102	2x4 ACT - UP - N		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
E-103	✓ ✓ ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
F-100	2x2 CELOTEX ABOVE 2x2 - N	7000	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
F-101	✓ ✓ ✓ ✓ - S		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
			PLM	<input type="checkbox"/>	TEM	<input type="checkbox"/>
G-100	WBJC DOWN NE	8850	PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
G-101	✓ DOWN SW		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
G-102	✓ UP NE		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>
G-103	✓ DOWN SW		PLM	<input checked="" type="checkbox"/>	TEM	<input type="checkbox"/>

ASBESTOS SAMPLING FORM



COMPANY CONTACT INFORMATION	
Company: REGULATORY COMPLIANCE SERVICES, INC.	Job Contact: Trey Fausett
Project Name: Pierce Co Admin - Old Church Building	trey@rcsenvironmental.net
Project ID #: 052516A	Tel: 229.563.2932

SAMPLE ID#	DESCRIPTION / LOCATION	VOLUME/ AREA	TEST	
			PLM	TEM
H-100	WINDOW GLAZE NORTH	62	<input checked="" type="checkbox"/>	<input type="checkbox"/>
H-101	WINDOW GLAZE SOUTH		<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
I-100	ASPHALT SHINGLES - N	18,000	<input checked="" type="checkbox"/>	<input type="checkbox"/>
I-101	✓ - S		<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
J-100	B.V. ROOFING - E		<input type="checkbox"/>	<input type="checkbox"/>
J-101	B.V. ROOFING - W		<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

Asbestos Consulting & Training Systems

40778.48889999999CERT/BIR

900 N.W. 5TH Avenue, Fort Lauderdale, Florida 33311

(954) 524-7208

This is to Certify that

O.P. (Trey) Fausett, III

Processed By:



To Authentic Certificate
www.seagulltraining.com
1-800-966-9933



X X X - X X - 7 3 0 0

14750 Beach Blvd # 56, Jax Beach, FL 32250

has successfully completed an English

Asbestos Building Inspection Refresher

24-Aug-15

TO

24-Aug-15

Meets state requirements of FL49-0001020/CN-0006273 and UT (6.0 core).

NDAAC Provider #451

Trainer(s): Alberto A. Ania

Training Address: 2233 Park Avenue Suite 202, Orange Park, FL, 32073

Successful course completion based on exam score on: 08/24/15

James F. Stump, Course Sponsor

This Certificate Expires:



23-Aug-16

Course Number: JE1535

Certificate Number: 165664



UNDER CIVIL AND CRIMINAL PENALTIES OF LAW FOR MAKING OR SUBMISSION OF FALSE OR FRAUDULENT STATEMENTS OR REPRESENTATIONS (18 U.S.C. 1083 AND 15 U.S.C. 2615), I CERTIFY THAT THIS TRAINING COMPLETES WITH ALL APPLICABLE REQUIREMENTS OF TITLE IV OF THE TOXIC SUBSTANCE CONTROL ACT (PART 745 OR 746) AND ANY OTHER APPLICABLE FEDERAL, STATE, OR LOCAL REQUIREMENTS.

[Handwritten signature of James F. Stump]