

ADDENDUM NO. 2
DATE: December 13, 2023
PROJECT NAME: Aztec Reservoir #1 Improvements, Phase 2
PROJECT NO. ITB-2024-843

TO: ALL PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and modifies or supplements the Project Manual or the Drawings as indicated below. All other provisions of the Contract Documents shall remain unchanged. This Addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof. Bidders shall acknowledge receipt of this Addendum in the appropriate space on the Bid Proposal form. Questions received thru 5 PM on 12/11/2023 are answered in this Addendum. This is the Final Addendum.

Please Note: Bid Opening will be at 3:00 PM , December 20th, 2023. A link to the Microsoft Teams' invite and Call in phone number with conference ID are listed below. Bids may be submitted and updated up until 3PM:

Microsoft Teams meeting

Join on your computer, mobile app or room device

[Click here to join the meeting](#)

Or call in (audio only)

[+1 505-312-9060,374778464#](tel:+15053129060,374778464#) United States, Albuquerque

Phone Conference ID: 374 778 464#

A. General

1. Pre-bid meeting minutes and sign in sheet have been attached to this addendum.

B. Questions:

1. 1) *Add #1 Q&A 8 Bid Item #18: New pipe is proposed as C900. Could you clarify DR rating?*

Response: DR-25 will be the minimum pressure class required for the PVC pipe utilized in bid item #18.

2. *Size 15" is not available in C900. Would you allow a different pipe type or size? If so what size or type?*

Engineering ▲

Spatial Data ▲

Advanced Technologies ▲

Response: Diamond Plastics has Pressure Rated (PIP) PVC pressure pipe in 15" SDR – 32.5 that would be the preferred product for 15" PVC pipe selection. Approved equals will be allowed. If field conditions require different pipe size/material that will be discussed and approved upon field discovery.

3. *Is the Prebid meeting going to be at City Hall or at the Aztec Water Plant?*

Response: The non-mandatory Prebid meeting was held at City Hall in the Commission room, at the same time and place as originally advertised.

4. *Will a copy of the sign in sheet from the 11/29/2023 conference be provided in the next addendum?*

Response: The Prebid meeting sign in sheet has been included as an attachment to the meeting minutes that were uploaded to Tracker on 12/1/2023 and have been attached to this addendum as well.

5. *What is the dosage of Xypex required for this project?*

Response: Manufacturer's recommended dosage for the Xypex admixture is 2-3% by weight of cement. Manufacturer's cut sheet states this equates to 10lbs per cubic yard. Manufacturer's cut sheet states to contact a technical representative for dosing in mixes containing fly ash. The manufacturer's cut sheet has been attached to this addendum for additional information pertaining to the admixture.

6. *Is there a profile of the existing 12" waterline? If not available, what is the assumed depth for bidding purposes?*

Response: Record Drawings for the 12" transmission line will be made available to the awarded contractor if requested. Assumed depth is 4' and bid item does specify at 'any depth'.

7. *Will there be any incidental cathodic protection scope involved on the existing watermain? Will holiday testing and repairs be required on the pipe coating?*

Response: There is not any cathodic protection, or holiday testing work anticipated within the scope of this project.

8. *Can the new manholes be casted as square vaults in lieu of circular?*

Response: Square vaults will not be accepted. Manholes shall be cast per detail 1, DWG. D-05.

9. *Where will the contractor be able to access construction water and who is responsible for the cost of water?*

Response: Water will be made available to the Contractor for sale by the City of Aztec. Contractor can fill trucks from a metered hydrant and reimburse the City at its normal rate cost.

10. *Where is the bid item for base course utilized in the project scope?*

Response: Base course is to be utilized for the Rd. 2960 northwest of the reservoir.

11. *Are there any traffic restrictions on Rd. 2960? What is required for traffic control compliance?*

Response: There are no traffic restrictions. BHI is informed that there is only 1 resident living on Rd. 2960 and their residence will be past the required excavation to install the new suction piping. Standard traffic control safety devices will be required while excavation activities are being performed and open trenches are present. Coordination with the resident will be required by the Contractor and the Contractor shall provide access to the resident.

12. *For NPDES compliance, please confirm the contractor will be responsible for all costs associated with installing and maintaining perimeter BMP's, construction entrances and concrete washouts? This will also apply to all seven ARV Manhole replacement locations in the additive alternate #1 pricing.*


Response: This is correct, the contractor is responsible for all costs associated with maintaining NPDES compliance. NPDES compliance is included as a bid item for the base bid (See bid item #5). Bid evaluations will determine if the additive alternate can be awarded, though it is not anticipated that the seven ARV replacements will constitute large enough disturbance (1 acre of disturbed land) to require an additional NPDES permit for that work.

13. *Please confirm the contractor is responsible for potholing costs.*

Response: The cost of any potholing required for this project will be considered incidental to the contract. Many of the existing utilities will be replaced within the construction limits of the reservoir. It is expected that during the demolition and excavation activities, horizontal location and vertical depth of the existing utilities will be identified.

Addendum No. 2
Aztec Reservoir #1 Improvements, Phase 2
December 13, 2023
Page 4

Bohannon Huston, Inc.

By:  12/13/2023
Andrew Swartswalter, PE Date

City of Aztec Reservoir #1 Improvements, Phase 2

Bohannon Huston, Inc.

Pre-Bid Conference - November 29, 2023

Initials	Name	Organization	Office Phone	Cell Phone	Email
AS	Andrew Swartswalter	Bohannon Huston, Inc.	505-798-7845	505-221-7801	aswartswalter@bhinc.com
KD	Karl Deissinger	Bohannon Huston, Inc.	505-798-7861	505-717-9583	kdeissinger@bhinc.com
	Joni Gay	City of Aztec	505-334-7656		jgay@aztecnm.gov
JJ	Jeric Jaramillo	City of Aztec	505-258-2010		jjaramillo@aztecnm.gov
	Ruben Salcido	City of Aztec			rsalcido@aztecnm.gov
	Rick Adair	TRC Construction Inc.	505-334-8220		radair@trc-construction.com
	Mike Hajovsky	CBKN Dirtworks, Inc.	505-867-2801		Mike@CBKNDirtworks.com
	Patricia Rivera	File Construction	505-554-1780		PatriciaR@fconst.com
	Christian Hasse	Hasse Contracting Co., Inc.	505-400-2336		chasse@hasseco.com
	Mindy Graft	Meridian Contracting, Inc.	505-872-2841		m.graft@meridiancon.net
	Rylan Edgmon	Smith Construction, Inc.	575-740-3492		Rylan@smithco.cc
	Brenda Penner	Smith Construction, Inc.	575-894-6161		brenda@smithco.cc
	Ben Byerly	Thorcon Shotcrete & Shoring	720-492-0316		Ben@thorconus.com
	LORENZO ZARPE	Southwest Liner Systems Inc	505-771-9122		lzarpe@slsliner.com mark@slsliner.com
	Kurt Shepherd	WCA Construction		970-747-4881	KShepherd@wcaconstruction.com
	Wes Sym	WCA Construction		970-737-7133	WesSym@wcaconstruction.com
	JOSE LOPEZ	MERIDIAN	505-872-2841	505-304-6939	J.Lopez@MERIDIANCON.NET
	Rick Adair	TRC Construction Inc.	505-334-8220	505-793-4795	radair@TRC-construction.com
	MIKE THIBAUT	Sychar, LLC	505-439-4033	505-634-8203	mike.thibault@Sychar.us
	Jake Ridley	Sychar LLC	505 916 6000 →		Jake.ridley@Sychar.us



ADMIX C-500/C-500 NF

CEMENTITIOUS CRYSTALLINE

Concrete Waterproofing

Description

Xypex is a unique chemical treatment for the waterproofing, protection and improvement of concrete. XYPEX ADMIX C-500/C-500 NF is added to the concrete mix at the time of batching. Xypex Admix C-500/C-500 NF consists of Portland cement, silica sand (excluding the NF grade) and various active, proprietary chemicals. These active chemicals react with the moisture in fresh concrete and with the by products of cement hydration to cause a catalytic reaction. This reaction generates a non-soluble crystalline formation throughout the pores and capillary tracts of the concrete that permanently seals the concrete and prevents the penetration of water and other liquids from any direction.

Xypex Admix C-Series

All variations of the Admix C-Series contain the same amount of reactive chemicals at their prescribed dosage rates and provide the same waterproofing and durability performance characteristics. Xypex Admix C-Series is available in regular or no-fines grades (NF). **Xypex Admix C-500/C-500 NF** is formulated to have minimal or no effect on setting time. **Xypex Admix C-1000/C-1000 NF** is formulated for concrete mix designs where a normal or mildly delayed set is desired. **Xypex Admix C-2000/C-2000 NF** is designed for warmer climates and projects where a slower hydration rate is typically required. See Setting Time and Strength for more details. Consult with a Xypex Technical Services Representative for the most appropriate Xypex Admix for your project.

Recommended for:

- Reservoirs
- Sewage and Water Treatment Plants
- Secondary Containment Structures
- Tunnels and Subway Systems
- Underground Vaults
- Foundations / Basements
- Parking Structures
- Swimming Pools
- Precast Components
- Bridge Structures

Advantages

- Resists extreme hydrostatic pressure
- Becomes an integral part of the substrate
- Highly resistant to aggressive and chemical environments
- Can seal static hairline cracks up to 0.5 mm
- Allows concrete to breathe
- Non-toxic
- No VOCs

- Less costly to install than most other methods
- Permanent
- Added to the concrete at time of batching and therefore is not subject to climatic restraints
- Increases flexibility in construction scheduling

For assistance with project requirements, please contact Xypex Technical Services Department.

Packaging

Xypex Admix C-500/C-500 NF is packaged in convenient sizes of various types of packaging, including repulpable paper bags and soluble bags. Contact your local Xypex Technical Services Representative or dealer for details and availability.

Storage

Xypex products must be stored dry at a minimum temperature of 45°F (7°C). Shelf life is one year when stored under proper conditions.

Dosage Rates

Xypex Admix C-500 (Regular Grade):

2 - 3% by weight of cement

Xypex Admix C-500 NF (No Fines Grade):

1 - 1.5% by weight of cement

NOTE:

i. For determining the appropriate dosage rate and for further information regarding concrete mixes containing fly ash / slag, enhanced chemical resistance, optimum concrete performance, or meeting the specific requirements and conditions of your project, consult with the local Xypex Technical Services Representative or Xypex's Technical Services Department.

ii. The recommended minimum dosage rate for Admix C-500 (Regular Grade) is 10 lbs. per yd³ (6 kg per m³); the maximum dosage is 20 lbs. per yd³ (12 kg per m³). For Admix C-500 NF (No Fines Grade), the minimum dosage is 5 lbs. per yd³ (3 kg per m³); the maximum dosage is 10 lbs. per yd³ (6 kg per m³).

iii. Under certain conditions the dosage rate for the Admix NF (No Fines Grade) may be as low as 0.8% depending on the quantity and type of total cementitious materials.

Material Properties

Visual Appearance	Light grey powder
pH	12.0 - 12.4
Chloride Content	<0.1%
VOC	none

Test Data

PERMEABILITY

U.S. Army Corps of Engineers CRD C48, "Permeability of Concrete", Aviles Engineering Corp., Houston, USA

Two concrete samples containing Xypex Admix and an untreated control sample were tested for water permeability. Both the treated and untreated samples were subjected to a pressure of 150 psi / 1.04 MPa (350 ft. / 106.7 m water head). Results showed moisture and permeated water throughout the untreated sample after 24 hours. However, the Xypex Admix samples showed no leakage, and water penetration of only 1.5 mm / 0.06 inches after 120 hours (5 days).

U.S. Army Corps of Engineers CRD C48, "Permeability of Concrete", Setsco Services, Pte Ltd., Singapore

Six Xypex Admix-treated and six untreated concrete samples were tested for water permeability. Pressure was gradually increased over five days and then maintained at 7 bars (224 ft. / 68.3 m water head) for 10 days. While the six reference samples showed water leakage beginning on the fifth day and increasing throughout the test period, the Xypex Admix samples showed no water leakage at any time during the test.

ACCI Water Permeability Test, "Water Permeability of Concrete", Australia Centre of Construction and Innovation, University of New South Wales, Sydney, Australia

Concrete samples containing Xypex Admix NF at a dosage rate of 0.8% and 1.2% were tested for water permeability against control samples. All the samples were subjected to a pressure of 10 bars (100 meters / 328 ft. water head) for 2 weeks. Water permeability coefficients were calculated and the Xypex Admix-treated concrete showed significant reduction in water permeability by up to 93% at a dosage rate of 1.2%.

STN EN 12390-8, "Testing of Hardened Concrete; Depth of Water Penetration Under Pressure", Technical and Testing Construction Institute, Bratislava, Slovakia

Concrete cubes were prepared with Admix C-1000 at 2% and Admix C-1000 NF at 1% along with control cubes. A water pressure of 0.5 MPa was applied for 72 hrs and specimens were subsequently split transversely to measure depth of water penetration. Depth results for C-1000/C-1000 NF were 10.3 mm and 25 mm respectively, whereas penetration on control samples was 113 mm. In using the Valenta equation to calculate the water permeability coefficient, the C-1000/C-1000 NF treated concrete showed a 20 to 120x reduction compared to the control concrete.

COMPRESSIVE STRENGTH

ASTM C 39, "Compressive Strength of Cylindrical Concrete Specimens", Kleinfelder Laboratories, San Francisco, USA

At 28 days, the compressive strength test of the concrete containing Xypex Admix measured 7160 psi / 49.5 MPa as compared to the reference sample at 6460 psi / 44.5 MPa (a 10% increase).

CHEMICAL RESISTANCE

CSN 73 1326, "Measuring Loss of Surface Due to Sulphate Attack of Concrete Treated with Admix C-1000 and Admix C-1000 NF", Betonconsult, Building Materials Testing Laboratory, Prague, Czech Republic

Concrete specimens treated with Admix C-1000 at 1% and 2%, and Admix C-1000 NF at 0.5% and 1% were cast along with non-treated concrete specimens. The specimens were exposed to a highly concentrated sulphate solution (i.e. 36,000 mg/l) for 4 months and samples were periodically weighed to determine mass loss. The Admix treated samples recorded a mass loss between 5 and 50 g/m² and showed no surface deterioration, while the non-treated specimens measured an average mass loss of 4,860 g/m² with significant surface deterioration.

HB 84-2006, "Durability Assessment of Reinforced Concrete Structure Containing Xypex Admix Exposed to 19 Years of Severe Marine Environment", Sharp and Howells Pty. Ltd. Chemical Laboratories, Victoria, Australia

Lascelles Wharf serves as a bulk chemical and grain dock. In 1995, as part of an extensive maintenance program and to protect new precast concrete panels from the extremely harsh and aggressive marine environment, the concrete was dosed with Xypex Admix C-Series at 1%. Recently tests were conducted to predict "initiation time to corrosion". Extracted cores were tested for chloride content at incremental depths into the concrete. Chloride content profiles, concrete cover, surface chloride content, and chloride corrosion threshold were used in a model based on Fick's 2nd law to predict the residual service life of this structure. The average initiation time to corrosion was estimated at 164 years; whereas, the structure had been designed for 50 years of service life.

NT BUILD 443, "Chloride Diffusion by NordTest with 16.5% NaCl Solution of 40 MPa Concrete Containing Admix C-1000 NF", Australia Centre for Construction Innovation, University of New South Wales, Sydney, Australia

The NordTest NT BUILD 443 is a standard accelerated method for evaluation of the chloride diffusion coefficient of concrete. In this test program, concrete mixes with 25% fly ash, 38% slag, and 60% slag were cast (total cementitious content = 435 kg, 0.4 w/c). Xypex Admix C-1000 NF at 0.8% and 1.2% by weight of cementitious materials were

compared to control mixes (for each cement system). All specimens were immersed in a 16.5% NaCl solution for 35 days. Chloride diffusion coefficient was calculated based on the chloride profile, utilizing Fick's 2nd law. Admix treated fly ash concrete showed 25% reduced chloride diffusion coefficient for both 0.8% and 1.2% addition. The Admix treated 38% slag concrete recorded a 67% lower chloride diffusion coefficient at 0.8% addition and 75% lower at 1.2% addition. The reduction of chloride diffusion coefficient was 42% and 53% for high slag mixes for 0.8% and 1.2% addition respectively.

“Sulfuric Acid Resistance Test”, Aviles Engineering Corporation, Houston, USA

Concrete containing Xypex Admix at different dosage rates including 3% specimens were tested against untreated control samples for sulfuric acid resistance. After immersion in the sulfuric acid, each sample was tested for weight loss on a daily basis until a weight loss of 50% or a definite response trend was obtained. The percentage weight loss of the samples containing Xypex Admix tested significantly lower than the control samples.

“Acid Resistance of Mortar Containing Xypex Admix C-1000 NF”, Construction and Maintenance Technology Research Center (CONTEC), Sirindhorn International Institute of Technology (SIIT) - Thammasat University, Bangkok, Thailand

An acid testing regime was part of an extensive program to determine the benefit of the Xypex Admix C-1000 NF dosed at 1% to improve the durability of concrete. Several comparative mixes were utilized in this evaluation, including: a plain Portland cement and a 30% fly ash mix. Cured samples were exposed to 5% H₂SO₄; the pH value of this acid solution was 0.25 and never greater than 0.54 pH. In this extremely acidic, corrosive environment, at 12 weeks the Admix samples reduced the weight loss by 48% compared to controls of the cement-only mortar, and 53% in the fly ash specimens.

CRACK SEALING

ASTM C1585 and ASTM C1202, “Evaluation of Self-healing Capability of Self-compacting Concrete Made with Blast-furnace Slag Cements Activated by the Xypex Crystalline Catalyst”, Instituto Tecnológico de Aeronautica, Sao Jose dos Campos, Brazil

Portland, blast furnace slag and slag-modified Portland concrete samples, treated with 2.5% Admix C-500, were evaluated for self-healing capabilities. Microcracks were induced by loading to 90% of ultimate compressive strength. Cracked samples were then immersed in water to trigger self-healing after 28, 56 and 84 days. Strength and ultrasonic pulse velocity tests were used to determine mechanical recovery; sorptivity and rapid chloride permeability were used to evaluate watertightness recovery. Results substantiated the ability of Xypex Admix to provide self-healing of cracked concrete.

“Testing of Xypex Admix C-1000 NF Crack Healing Capabilities”, CH Karnchang (Lao) Company Ltd., Xayaburi Laboratory, Ban Xieng Yeun, Vientiane, Laos

Prior to construction of a Mekong River dam, testing was undertaken to substantiate the ability of Xypex Admix to self-heal static cracks. Three large concrete slabs treated with Admix C-1000 NF at 0.8% were cast along with three control slabs. Following curing, a force was applied at the mid-point of each slab to create cracks with widths from 0.2 to 0.5 mm on the surface. Water was ponded above the cracked area. Initially all cracks leaked; at 4 days all dripping had ceased from the cracks of the Xypex treated panels, while leaking continued through the cracks of the control slab until the end of the test period (25 days). SEM photographs showed significant crystalline growth throughout the cracks of the Admix treated slab.

SCANNING ELECTRON MICROSCOPY

SEM “Microscopic Examination of Crystalline Products in Three Xypex Admix Modified Concrete Mortars”, Australian Centre for Construction Innovation, University of New South Wales, Sydney, Australia

Slag and fly ash blended cement samples were treated with Xypex Admix and examined for evidence of crystalline growth at ages ranging from 8 months to 2 years. Samples were sliced and/or split and examined at magnifications between 500x and 5000x. Characteristic Xypex crystalline growth was observable on all Xypex treated samples, providing evidence of Xypex crystalline reactions with fly ash and slag blended cements.

FREEZE/THAW DURABILITY

ASTM C 666, “Freeze/Thaw Durability”, Independent Laboratory, Cleveland, USA

After 300 freeze/thaw cycles, the Xypex Admix-treated samples indicated 94% relative durability.

POTABLE WATER EXPOSURE

NSF 61, “Drinking Water System Component-Health Effects”, NSF International, Ann Arbor, USA

Exposure testing of potable water in contact with Xypex-treated samples indicated no harmful effects.

Directions for Use

Xypex Admix C-500/C-500 NF is added to the concrete at the time of batching. It is important to obtain a homogeneous mixture of Xypex Admix with the concrete. Do not add dry Admix powder directly to wet mixed concrete as this could cause clumping and thorough dispersion may not occur. The sequence of procedures for addition will vary according to the type of batch plant operation and equipment. The following methods have been used successfully in the past and it is recommended that the local Xypex Technical Services Representative be consulted about the best method to use.

1. ADDITION TO COARSE AGGREGATE BELT Add Xypex Admix in bulk powder form, soluble bags or repulpable bags directly to the coarse aggregate conveyor belt manually or through computer controlled mass batching system. Account for worker health and safety issues with moving belts and wind-blown dust issues.

2. TRUCK ADDITION (AT PLANT) Add Xypex Admix in bulk powder form, soluble bags or repulpable bags to the drum of the ready-mix truck immediately prior to driving the truck under the batch plant and adding the balance of the materials or the premixed concrete in accordance with standard concrete batching practices. Measures to ensure soluble bags or repulpable bags are dispersed include adding the bags as far forward in the drum as possible, adding a small amount of batch water with the bags, and spinning the drum prior to adding remaining ingredients. Avoid delays in adding other components and utilize high speed mixing to ensure homogeneity of mix. Additional high speed mixing time may be required when using repulpable bags. Where there may be insufficient water for thorough dispersion of the bulk powder, a water slurry can be made with the Admix and added to the truck mixer drum prior to batching. Account for added water in the mix design and slump.

3. ADDITION TO CENTRAL MIXER Add Xypex Admix in bulk powder form, soluble bags or repulpable bags along with the other components. Mix as per standard batching practices to ensure thorough dispersal of the Admix resulting in a homogeneous mixture. Additional high speed mixing time may be required when using repulpable bags. Account for worker safety issues when accessing the equipment.

NOTE:

- i. Although addition on site in powder form is not normally recommended, it may be necessary. In such a case, add Xypex Admix to truck in slurry form (e.g. 3 parts powder to 2 parts water by volume). Mix concrete for a minimum of 5 minutes on high speed or until thoroughly dispersed. Account for added water in the mix design and slump.
- ii. Concrete containing the Xypex Admix does not preclude the requirement for design of crack control, construction joint detailing, proper placement, consolidation and curing of the concrete and measures for repairing defects such as honeycombing, tie holes, cracks beyond specified limits.
- iii. Further guidelines are available that address the use of Xypex Admix for a specific situation, (e.g. dry mixes, use of ice in hot ambient conditions, cold-weather concreting, etc.). Consult with a local Xypex Technical Services Representative or Xypex's Technical Services Department for further information.

Setting Time and Strength

The setting time of concrete is affected by the chemical and physical composition of ingredients, temperature of the

concrete and climatic conditions. Xypex Admix C-500/C-500 NF is designed to have minimal or no effect on setting time. Concrete containing the Xypex Admix C-500/C-500 NF may develop higher ultimate strengths than plain concrete. Trial mixes should be carried out under project conditions to determine the setting time and strength of the concrete dosed with Xypex Admix C-500/C-500 NF. Consult with a Xypex Technical Services Representative for the most appropriate Xypex Admix for your project.

Limitations

When incorporating Xypex Admix, the temperature of the concrete mix should be above 40°F (4°C).

Technical Services

For more instructions, alternative installation methods, or information concerning the compatibility of the Xypex treatment with other products or technologies, contact the Technical Services Department of Xypex Chemical Corporation or your local Xypex Technical Services Representative.

Certification

Xypex Admix C-500/C-500 NF is certified as a water retaining admixture according to EN 934-2+A1. The certification of the product and regular audits of the FPC are carried out by Notified Body 1020 TZUS (060-051352).

Safe Handling Information

Xypex is alkaline. As a cementitious powder or mixture, Xypex may cause significant skin and eye irritation. Directions for treating these problems are clearly detailed on all Xypex pails and packaging. The Manufacturer also maintains comprehensive and up-to-date Safety Data Sheets on all its products. Each sheet contains health and safety information for the protection of workers and customers. The Manufacturer recommends you contact Xypex Chemical Corporation or your local Xypex Technical Services Representative to obtain copies of Safety Data Sheets prior to product storage or use.

Warranty

The Manufacturer warrants that the products manufactured by it shall be free from material defects and will be consistent with its normal high quality. Should any of the products be proven defective, the liability to the Manufacturer shall be limited to replacement of the product ex factory. The Manufacturer makes no warranty as to merchantability or fitness for a particular purpose and this warranty is in lieu of all other warranties expressed or implied. The user shall determine the suitability of the product for his intended use and assume all risks and liability in connection therewith.

