



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: February 24, 2022

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #2 to Invitation For Bid, # 37607, Resurface Fellsmere Grade Recreational Area Parking Lot

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: Can the entire park be closed for the paving and striping operations? The paving should take only 2 days and the striping 1 day. It is essential for maximum productivity to close the park for both paving (2 days) and striping (1 day), this will increase production for cost effectiveness and you cannot pave or stripe on a continuous wet surface. It would be a tremendous inconvenience to both the construction process and any boater trying to launch or load during the construction operation.

Try to maintain the asphalt surface due care needs to be taken, vehicles turn the wheel while stopped, sharp turns and erratic movement on fresh pavement. This is difficult in a public park, but will help the long term life of the pavement

A1: This request is approved. The parking lot can be closed for up to three days to allow for the work to be completed. However for this to occur, work should be planned to be completed no earlier than May 16, 2022. In addition, the contractor shall provide the District 7-days notice to allow for the proper public noticing.

Clarifications:

1. Attachment A, Statement of Work, page 46, Completion Date has been changed to May 31, 2022.
2. Qualifications General, page 17, delete ~~Respondent's tax identification No.~~

Attachments:

Attachment A, Statement of Work, page 46, revised Addendum 2

Qualifications General, Page 17, revised Addendum 2

Schematic Fellsmere Grade Parking Lot

NOTE: The Bid Due Date **remains** 2:00 p.m., **Wednesday, March 9, 2022**

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.

- e. The contractor is responsible for ensuring the quality and acceptance of the asphalt mixture including field testing of asphalt pavement to ensure compliance with specifications. Contractor will coordinate with the District regarding the timing and location of testing. The asphalt mixture will be accepted at the plant with respect to gradation, asphalt content and volumetrics. The asphalt mixture will be accepted in the field with respect to density of roadway cores. For this project four (4) cores shall be obtained within 24 hours of placement at random locations directed by the Project Manager. These samples shall be tested in accordance with current section 334-5.1.1.
- Restripe Parking Lot (Section 710 and 971) in same configuration as currently exists or as directed by the Project Manager. This includes parking stalls (6-inch width), ADA parking stalls, directional arrows and speed humps (yellow).
- Demobilize from site. The Contractor shall take care to protect all existing structures, roads, utilities and other improvements from damage. Additionally, the Work will be considered complete only after all rubbish and unused material associated with the Work has been removed and the premises left in a condition satisfactory to the District. All property disturbed or damaged during prosecution of the Work shall be restored to its former condition or better at no additional expense to the District.

IV. DISTRICT RESPONSIBILITIES

- Provide access to contractor.
- Participate in preconstruction meeting.
- Direct placement of leveling course
- Oversee all aspects of the construction.
- Conduct final walk-through with Contractor

V. TIMEFRAMES AND DELIVERABLES

All construction activities outlined above shall be completed by May ~~15~~ 31, 2022.

VI. BUDGET AND INVOICE REQUIREMENTS

For satisfactory performance, the District agrees to compensate Contractor in accordance with the Contract terms.

PAYMENT OF INVOICES

Contractor shall submit monthly itemized invoices by one of the following two methods: (1) by mail to the St. Johns River Water Management District, Director, Division of Financial Management, 4049 Reid Street, Palatka, Florida 32177, or (2) by e-mail to acctpay@sjrwmd.com. Each invoice shall be submitted in detail sufficient for proper pre-audit and post-audit review. If necessary for audit purposes, the District may require and Contractor shall provide additional supporting information to document invoices.

PROJECT MANAGER

James Rider, Program Manager
Bureau of Operations and Maintenance
321-863-0029 (cell)
321-984-4941 (office)
jrider@sjrwmd.com (email)

FIELD SUPERVISOR

Harman Bansil, O&M Specialist
Bureau of Operations and Maintenance
321-978-1917 (cell)
321-473-1335 (office)
hbansil@sjrwmd.com (email)

QUALIFICATIONS — GENERAL

Include this form in the response

As part of the bid, Respondent shall complete the following so that the District can determine Respondent's ability, experience, and facilities for performing the Work.

Name of Respondent: _____

Respondent's tax identification No.: _____

Year company was organized/formed: _____

Number of years Respondent has been engaged in business under the present firm or trade name: _____

Total number of years Respondent has experience in similar placing asphalt concrete is work described in the INSTRUCTIONS TO RESPONDENTS: _____

Has Respondent previously been engaged in the same or similar business under another firm or trade name? If so, please describe each such instance.

Has Respondent ever been adjudicated bankrupt, initiated bankruptcy, or been the subject of bankruptcy proceedings on behalf of the current entity submitting this bid or a prior entity that Respondent substantially operated or controlled? If yes, please describe the nature and result of those proceedings and the entity involved.

Describe the background/experience of the person or persons who will be primarily responsible for directing the Work that will be performed pursuant to this bid. This inquiry is intended to encompass the project manager and/or superintendent who will be engaged on a daily basis in directing performance of the Work.



Fellsmere Grade Parking Lot