

FALL 2020 RESURFACING ADDENDUM

1. The quantities for double yellow and edge line on W. Carolina are high for the area being paved. Are we re-striping the entire length of the road?
 - a. The temporary paint is only for the section that is being paved, but the thermo quantity is high because Russ wants to widen and freshen the existing edge-line on the remainder of Carolina.

2. Smithfield Ave., you have 170# Type C asphalt and 2" milling. All of the other roads with 170# have 1.5" milling. Which do I need to use?
 - a. It should 1.5" milling.

3. The bid form asks for 225# Surface Type C on West Carolina. Your specs read that roads with 225# should be Type B.
 - a. This should be surface type B instead of surface type C