

**Bid #4788 Concrete Pad**  
**Second set of Questions and Answer**  
**August 25, 2017**

1. I wish to confirm the dimensions of the footer to be placed around the pad.

Answer: 12" x 12" footer

2. I wish to confirm that the loading dock is to be 10'x10'x38" with 8" walls, filled with gravel and 6" thick top.

Answer: Dock specs - 10'x10'x38" with 8" walls, filled with gravel and 6" thick top is correct.

3. On both proposals it is mentioned that plans are available for viewing. Is there a way to get a copy or set a time to view them and who is our best contact to see the site?

Answer: Please contact Geoff Trabalka at (865) 256-1906.