## **ADDENDUM NO. 2**

# TO THE DRAWINGS AND SPECIFICATIONS FOR THE

Tates Creek High School Track & Field Improvements 2/9/2023

## To All Plan Holders of Record:

This Addendum modifies bid documents dated 1/24/2023 for the above project and shall become part of said documents in the preparation of proposals and execution of work of the subject project.

## General:

1. Refer to attached Addendum Sheet from CMTA.

## **Specifications:**

1. N/A

## **Drawings**:

- 1. Refer to Drawing Sheet SD0.2 Site Demolition Plan
  - a) Refer to Construction Access Note at the northwest corner of the track. Revise note as follows:
    - i) Contractor is to take special care at the construction entrance to protect the existing track. Contractor is to construct abutments and provide a bridged condition over the existing track pavements and rubber surface. Contractor shall repair/replace any rubber track surface, asphalt pavements, and concrete curbs that are damaged by construction activities.
- 2. Refer to Drawing Sheet SD1.1 Site Development Plan
  - a) Replace drawing sheet in its entirety with the attached SD1.1
    - i) Clarifies extents of full depth replacement of the track surface.

## END OF ADDENDUM

ADDENDUM PAGE 1

## TATES CREEK HIGH SCHOOL TRACK & FIELD IMPROVEMENTS ADDENDUM #2 – MEP 2/9/2023

## Item #1 Refer to the Electrical Drawing UE1.0

A. Tagged Note U16 shall read as follows: REMOVE EXISTING ATHLETIC LIGHTING. REMOVE CONDUITS AND FOUNDATION TO 18" MINIMUM BELOW GRADE. REMOVE CONDUCTORS.

#### Item #2 Refer to the Electrical Drawing UE2.0

- A. All work described in Tagged Note U73, U74, and U76 shall be provided by contractor.
- B. Refer to Tagged Note U77, speaker cable shall be #14awg, 300v, outdoor rated cable. Contractor shall coordinate exact requirements with existing equipment.
- C. Refer to Tagged Note U70. The 400a feeder described shall be extended from an existing disconnect located in the exterior electrical closet on the south side of the Fieldhouse behind a set of double doors. Panelboard FB shall be NEMA 3R rated and shall be located on the exterior of the Fieldhouse adjacent to the Musco Football Ahtletic Lighting Control panel.

## Item #1 Refer to the Electrical Drawing UE3.0

A. The lighting circuits (for pole F1, F1 High Jump, F2, F3, F4, T1, and T2) in panel FB shall be extended through the Musco Football Athletic Lighting Control Panel, then to poles. Refer to FB panel schedule for breaker sizes, circuit sizes, etc.

END OF ADDENDA ITEMS

