

MARYVILLE SCHOOL LIFT STATION
CITY OF GEORGETOWN
GEORGETOWN, SOUTH CAROLINA

SUBJECT: ADDENDUM NO. 1

8/10/2021

To the Plans and Specifications for:
Maryville School Lift Station
Georgetown, S.C.

To: PROSPECTIVE BIDDERS AND OTHER CONCERNED PARTIES

This ADDENDUM forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. Bidders shall acknowledge receipt of the ADDENDUM in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

A. General Requirements

1. A copy of the August 4th pre-bid minutes are attached for information purpose

B. Technical Specification Requirements

1. Document 11307, Submersible Pump Station

- a. Question: I see that the guide rails need to be stainless steel; however, it isn't clear about the sliding bracket and discharge floor elbow. Does the pump sliding bracket and floor elbow need to be stainless steel?


Answer: The sliding bracket and discharge elbow are normally made of cast iron and part of the pump package that is installed. Everything else shall be stainless steel.

- b. Question: Can you confirm the flow rate for each pump? The schedule and specs say 780 GPM; is that two pumps at 780 GPM each or two pumps at 390 GPM each?

Answer: Each pump needs to have a capacity of 780 GPM.

Bids will be received until 2:00 pm, August 19th, 2021

FOR THE OWNER
THE WOOTEN COMPANY



Perry Mayhew, P.E.

END OF DOCUMENT

Wednesday, August 4, 2021



Maryville School Lift Station Replacement
Project #1815
SC Rural Infrastructure Authority (RIA)
Grant #S-21-1287

Request for Bid (RFB)

Meeting Minutes

Non-Mandatory Pre-Bid Conference

Via Go to Meeting: 10:00 am (EST), Wednesday, August 4, 2021

• **RIA Grant Information**

Schedule of milestone events and receipt and opening of bids included in the project manual and on the website as well. The project is partially funded by RIA. RIA will need to be involved in the construction approval as well as City Council before contractor starts.

• **Project Summary**

Main task

- Excavate for new wet well
- Install new wet well and equipment
- Shut down existing facility with bypass pumping
- Connect old wet well to new wet well

Need to secure the area and bypass pump coordination.

Reed Waterbury wants a site visit. Will Gunter to handle site visits but one official visit may be scheduled if there is enough interest.

Please send an email for questions so we can add to an addendum, purchasing@sc.gov. Deadline for questions is Friday, August 6th, addendum will be sent out Tuesday, August 10th.

Wednesday, August 4, 2021



- **Scope of Services**

Equipment- 2 duplex submersible pumps to install in main wetwell-780 GPM 126 ft head and 58 HP, need to adhere to voltage requirements, non-clog pump, any non-ABS pump needs to be approved by engineer.

How to submit for alternate pump approval? If the contractor would like alternate equipment approved prior to bidding then, per specification 01330 Submittal Procedure, the submittal will need to be sent to the engineer 10 days prior to bidding.

Pump calls for Class 1 explosion proof: What is the reasoning behind this designation? The designation is due to the hazardous location of the pumps due to the wet well.

- **Selection and award of alternates**

- **Questions**

- **Schedule of Milestone Events**

Milestone events- Friday deadline for questions, Tuesday is deadline for answers, bids due Thursday, August 19th.

- **Receipt and opening of bids**

All bids will be received electronically and the City recommends submitting at least 30 mins prior to the deadline to ensure there are no problems with receipt of bids. Once bids are received they will be opened at the designated time and presented to council Thursday, September 16th. Completion by Mid-May with some additional closeout documentation done by August of next year.

Please note - Impromptu, unwritten questions are permitted and verbal answers may be provided, but are only intended as general direction and will not represent the official City of Georgetown position. The only official position of the City is that which is stated in writing and issued in any addenda.

No other means of communication, whether oral or written, shall be construed as a formal or official response/statement and may not be relied upon.