



## **RFB2104 Fencing Projects**

### **ADDENDUM 1 October 14, 2020**

At the mandatory pre-bid meeting on October 13, 2020, the following changes/clarifications were made to the above referenced RFB:

- 1) The Solicitation # is 2104, not 2103 as listed at the top of the first page of the bid.
- 2) Bids will be accepted via email to [kacey.austin@spart2.org](mailto:kacey.austin@spart2.org) . If emailing, please be sure that you receive a confirmation email that the documents have been received. In an email is not received, the documents have not been received.
- 3) The fencing at both locations should be SS40, 9 gauge core, 8 gauge finish, knuckle-knuckle wire, 1 5/8" top rail, 2" gate frame, 6 gauge bottom tension wire, with 3" terminal posts.
- 4) A SC General Contractors' License is NOT required.