



ADDENDUM NO. 2

Issue Date: December 21, 2021

Project Name: Hallstrom Farmstead Parking and Restrooms

Bid Number: 2022019

Bid Opening Date: January 28, 2022 (**Updated**) at 2:00 p.m.

This addendum is being released to answer questions received to date and to modify the Bid Opening Date. The information and documents contained in this addendum are hereby incorporated in Invitation to Bid. **This addendum must be acknowledged where indicated on the Bid Form, or the bid may be declared non-responsive.**

Bid Opening Date

The deadline for receipt of bids is extended to January 28, 2022. Modifications to the scope and updated documents will be released via addendum 3 at a later date.

Questions and Answers

1. Unable to find what's called out for tile work in the bathrooms. I see the main floors are finished concrete but there's no notes on the tile work. Please advise.
There is no tile work, refer to finishing notes sheet A-1.
2. There is a line item on the bid form for striping. The parking area is supposed to be shell. Are we supposed to stripe the shell or is this for the handicap symbol and possibly a stop bar?
The Signing and Striping Line item (Item #14) is for striping and signing the handicap stall (see detail on sheet C11 of the plans) and for signing and striping the entrance (stop bar, stop sign and 25 LF of double yellow striping). See detail on sheet C6 of the plans. The stop bar and stop sign shall be placed according to Indian River County Traffic Standards, most current edition. There shall be no markings on the shell portion of the parking lot. The wheel stops will delineate parking spaces.
3. Line item on bid form for walkway signs. Please provide a detail and number of signs or locations.
Please see response for question 2.