

CLAYTON COUNTY WATER AUTHORITY

Request for Bids

ANNUAL CONTRACT FOR FLOW MONITORING SERVICES

**Bid Opening: Tuesday, October 27, 2015 at 2:00 p.m. local time
1600 Battle Creek Road, Morrow, Georgia 30260**

A D D E N D U M # 1

Dated: October 21, 2015

Acknowledgment of receipt of this addendum *MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.*

QUESTIONS:

1. **Is there a past Bid? If so how do we request a copy?**

Answer:

The Clayton County Water Authority opened sealed bids on October 23, 2013. Bids were evaluated using pay items and quantities estimated to represent historical /annual work to be completed. A summary of the costs is presented in the table below:

All unit prices are on a per unit cost basis		Woolpert		ADS	
Items	Est. Annual Quantity	Unit Cost	Extended Amount	Unit Cost	Extended Amount
Item 1 Monthly Comprehensive Service for Flow Monitors	96	\$ 384.57	\$36,918.72	\$ 420.00	\$40,320.00
Item 2 Data Processing and Analysis	12	\$1,410.33	\$16,923.96	\$1,050.00	\$12,600.00
Item 3 Monthly Report	12	\$ 722.00	\$ 8,664.00	\$ 710.00	\$ 8,520.00
Total Bid Amount			\$62,506.68		\$61,440.00

Bid was awarded to ADS Environmental Services based on the unit prices bid as shown.

2. **Is a Bid Bond or Performance Bond Required?**

Answer:

A Georgia Bid Bond is not required for this bid. Payment and Performance Bonds are not required either for this bid.

3. **Page 7 Division 2 # 12: Bids for public works whose price exceeds \$100,000.00 must be accompanied by a certified check, cashier's check, or acceptable bid bond in an amount not less than five percent (5%) of the amount bid.**

Answer: See response to question #2.

CLAYTON COUNTY WATER AUTHORITY

Request for Bids

ANNUAL CONTRACT FOR FLOW MONITORING SERVICES

**Bid Opening: Tuesday, October 27, 2015 at 2:00 p.m. local time
1600 Battle Creek Road, Morrow, Georgia 30260**

A D D E N D U M # 1

4. Page 16 - BID FORM - Work Item

What category do we put the cost for Maintenance of equipment?

Answer: In Work Item #1 Monthly Comprehensive Service for Flow Monitors.

5. Was there a Pre-Bid meeting page 5 2.1.1 item #3, if so are the minutes available?

Answer: No, CCWA did not have a pre-bid meeting for this RFB.

6. Current configuration of each location equipment used/needed for the Flow Monitoring Systems?

Answer: The Authority owns seven (7) ADS 4000 Monitors and one (1) Flowshark Monitor that are currently being used in the six (6) sites (2 units are in storage) and can be interchanged as needed for the six (6) sites.

7. Are there any known problems with the existing system? If so, what including location?

Answer: The existing system will occasionally have rags and solids gathered on the sensors. This is common in flow monitoring of sanitary sewer systems and remedied by equipment inspections included in Work Item #1 Monthly Comprehensive Service for Flow Monitors.

8. In case of emergencies, is there 24/7 remote access to systems?

Answer: All sites are located in manhole structures with 24/7 access.

9. Is a Georgia Contractors License required to complete the Annual Contract for Flow Monitoring Services?

Answer: No, it is not required.

SIGNATURE

COMPANY NAME

DATE