



**PERALTA COMMUNITY COLLEGE DISTRICT**

**DISTRICT-WIDE NETWORK INFRASTRUCTURE UPGRADE**

**ADDENDUM**

**RFP NO. 21-22/04**

**Peralta Community College District**

**333 East 8th Street Oakland, CA 94606**

September 20, 2021

**ADDENDUM No. 3**

This addendum supersedes items of the original RFP documents wherein it is inconsistent with it. All other conditions remain unchanged. The following changes, modifications, corrections, additions, or clarifications shall apply to the contract documents and shall be made a part of and subject to all the requirements thereof as if originally specified or shown. It is the responsibility of the proposer to review the list of attachments to ensure that the addendum is full and complete. This Addendum modifies the original RFP Documents for the above project.

**Acknowledge receipt of this addendum in the space provided on Acknowledgement and Signature Form. Failure to do so may subject proposer to disqualification.**

**Revisions/Clarifications to RFP documents:**

- Page 106 - Delete "Minimum backup time of 3 minutes at 100% load and replace with "Minimum backup time of **30 minutes** at 100% load

**Berkeley City College**

- Page 106 – Add five (5) additional UPS Battery packs to the original count of 5 to make a total of **10**

**END OF DOCUMENT**