

ADDENDUM NO. 3

DATE: July 25, 2018
TO: All Potential Bidders
FROM: Boyce H. Evans, Purchasing Agent City of Knoxville
SUBJECT: Addendum No. 3 – Fire Department Headquarters Roof Upgrade
BIDS TO BE OPENED: August 2, 2018, at 11:00:00 a.m. (Eastern Time)

This addendum is being published to respond to questions asked by potential bidders regarding the above referenced Invitation to Bid. This addendum becomes a part of the contract documents and modifies the original specifications as noted.

Question: Would the City accept the following as an “approved substitution” for the roofing material for this project?

PROPOSED SUBSTITUTION GAF® Specification: TFATI60. Products include EverGuard® TPO 60 mil Membrane Data Sheet, EnergyGuard Polyiso Insulation 20 & 25 PSI Data Sheet – 2016, EverGuard® Diamond Pledge™ NDL Roof Guarantee, EverGuard® TPO Bonding Adhesive Sell Sheet. This system is eligible for up to a (20) year Guarantee.

Response: Yes, the City will accept this product as an approved substitution provided the 20 year warranty guarantee, mentioned above, comes with the product.

END OF ADDENDUM 3