


ADDENDUM NO. 1

DATE: July 11, 2018
TO: All Bidders
FROM: Boyce H. ~~Evans~~ , Purchasing Agent, City of Knoxville
SUBJECT: Addendum No. 1 – Fire Department Headquarters Roof Upgrade
BIDS TO BE OPENED: **August 2, 2018, at 11:00 a.m. (Eastern Time)**

This addendum is being published to respond to questions asked by potential bidders regarding the above-referenced Invitation to Bid. This addendum becomes a part of the Contract Document and modifies the original plans and specifications as noted.

Questions Received

1. Q: Will a PVC system be accepted as an approved equivalent to the proposed TPO system?
A: No. It is the City of Knoxville's position that because PVC becomes more brittle with age and sun exposure, the TPO system is a more desirable product.

END OF ADDENDUM NO. 1