



# CITY OF CONROE

Est. 1904

City of Conroe  
PO Box 3066  
Conroe, Texas 77305

**ADDENDUM NO. 1**

DATE ISSUED: September 10, 2020

PROJECT NAME: 917-2020 Annual Landscaping Services Bid

This revision shall be considered part of the contract documents for the above named project and shall be incorporated integrally with the previously issued documents. Wherein provisions of the revisions differ from the provisions of the original documents and/or the provisions of previously issued addendum, the provisions of this revision shall govern and take precedence.

Clarification:

Pg. 11 - Mulching – The contractor shall provide and install mulch in a uniform thickness maintaining a minimum depth of two (2) inches. Mulch shall be coarse screened native hardwood mulch with particle size no greater than one (1) inch in diameter for a consistent appearance. The City of Conroe reserves the right to request a mulch sample prior to the contractor’s installation and to reject any product not meeting these specifications.

By the signature affixed below, Addendum No. 1 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Respondent/Contractor

Date  
*Kristina Colville*

Kristina Colville, Purchasing manager