



## WILLIAMSON COUNTY

Leslie Mitchell, CPPO, CPPB  
1320 West Main Street, Suite 130  
Franklin, Tennessee 37064  
(615) 790-5868  
lesliem@williamson-tn.org

November 21, 2017

### Addendum #1 for Bid for Fire Alarm at Public Library Bid Opening Date November 30, 2017

Following are questions received and Williamson County's responses regarding the above bid:

- Q. What are the part numbers for the equipment specified?  
A. *Silent Knight non-proprietary*
- Q. Is there any demo required?  
A. *Remove old system and replace with new*
- Q. Is the cable/wire infrastructure to be replaced?  
A. *No*
- Q. Is current system design up to code?  
A. *As far as we know. It is up to the contractor to make sure it is up to code when finished.*
- Q. What is the work schedule (after hours, weekends...)?  
A. *Preferably during open hours, but other arrangements can be made for after hours if needed.*
- Q. Are plans of the existing buildings and/or fire alarm system plans available (hard copy, PDF, AutoCAD)?  
A. *Plans will be provided by CD and uses DWG format.*
- Q. Will fire watch be required?  
A. *Williamson County will provide Fire Watch if needed.*

**Building consists of 12+/- manual pull stations, 30 +/- Photo smoke detectors, 24+/- duct detectors, 2 +/- heat detectors, 3 +/- waterflow switches, 4 +/- Supervisory switch. 12 +/- strobes, 45 +/- Horn/strobe.**

**Contractor will provide schematic of devices to correspond with panel legend.**

**Upgrades of new devices to bring building up to code if needed.**

**Contractor responsible for permits and drawings.**

Leslie Mitchell, CPPO, CPPB, Purchasing Agent

LM/lw

**REVISED**  
**Minimum Specifications**  
**Replacement of Fire Alarm System**  
**Williamson County Public Library, 1314 Columbia Avenue, Franklin, TN 37064**

Mandatory pre-bid conference will be held at the site on Tuesday, November 21, 2017 at 1:00 p.m.

Williamson County Property Management is in the process of standardizing all fire alarm panels to the Silent Knight System as current systems expire.

**Scope of work:**

Removal of current fire alarm system and replacement with an equivalent Silent Knight Non-Proprietary Panel and Equipment. All bids to include Fire Watch if needed. Contractor responsible for all permits.

**Items to include for replacement:**

- 1 Silent Knight Fire Alarm Control Panel
- 2 Power Supplies
- 1 Remote Annunciator
- 12 Manual Stations
- 35 Smoke Detectors
- 3 Flow Switch Connections
- 8 Tamper Switch Connections
- 8 Heat Detectors
- 46 Duct Smoke Detectors
- 23 Remote Indicators
- 33 Relays
- 45 Horn/Strobes
- 12 Strobes

**Total Bid \$** \_\_\_\_\_

**Estimated time to complete work after notice to proceed** \_\_\_\_\_

The bidder has received the following addenda:

Addendum # \_\_\_\_\_ Dated \_\_\_\_\_

Addendum # \_\_\_\_\_ Dated \_\_\_\_\_

Company Name \_\_\_\_\_

Physical Address \_\_\_\_\_

Remittance Address \_\_\_\_\_

Authorized Signature \_\_\_\_\_

Printed Name \_\_\_\_\_

Phone \_\_\_\_\_ Fax \_\_\_\_\_

Email Address \_\_\_\_\_

Date \_\_\_\_\_