



Georgetown County, South Carolina

129 Screven Street, Suite 239
Post Office Drawer 421270
Georgetown, SC 29442-4200
(843) 545-3083 • Fax (843) 545-3500
E-Mail • purch@gtcounty.org
Website • <http://www.gtcounty.org>

ADDENDUM #2 TO BID #23-028

BID NUMBER: 23-028

ISSUE DATE: Friday, July 14, 2023

OPENING DATE: Wednesday, July 20, 2023

OPENING TIME: 3:00 PM ET

Pre-Bid Conference/Site Inspection: [Closed]

PROCUREMENT FOR: East Andrews Drainage Improvements-Phases 1 & 2

This addendum will amend **Bid #23-028, East Andrews Drainage Improvements-Phases 1 & 2** originally issued on Tuesday, June 20, 2023. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: www.gtcounty.org, select "Bid Opportunities" from the Quick Links section.

Question 1: Are there shut down restrictions/durations for Domestic Water Relocation Items NO. S000011 & S000012?

Response: Contractor is responsible for providing advance notice to Town of Andrews for any water outages so that the Town can properly inform their citizens.

Down times for water relocates will be scheduled once size and location of the water lines is confirmed, which will not be confirmed until the pot holing is done for utilities.

Question 2: Could you please provide testing specifications for the Domestic Water Relocation? Specifically will the line be required to be testing prior to tie-in and then tested again after tie-in is complete?

Response: For a main being opened, the Town of Andrews requires how the line is being disinfected. If it is a service line, then the Town would require flushing lines at the meter box. The Town requires chlorine residuals for both methods.

Question 3: Will the bid opening date be extended out?

Response: No.
