

WEST WELCH REED ENGINEERS, INC.
ADDENDUM NO. 1

Project: **Maynardville Elementary School**
HVAC for 4 Classrooms

Project Number: 121-077

Date: **Dec. 15, 2021**

The above named documents are hereby modified, amended, or supplemented as enumerated herein. All such modifications, amendments, and/or supplements shall be considered as though originally specified and/or shown on the drawings or in the specifications. This addendum shall be acknowledged on the bid form.

1. Refer to Drawing M1, Rev.1:

- A. The indoor units shall be provided with a condensate pump, Aspen Mini White Pump Kit.
- B. An "M-Net" adapter shall be provided with each HVAC unit.
- C. Provide a TE-200A Centralized Controller for Mitsubishi ductless split systems. The controller shall interface with the existing Johnson Controls Metasys System.
- D. Added "Typical Through Roof Condensate Detail".

2. Refer to Drawing M2, Rev. 1:

- A. See Demo Key Note #2: Note has been modified to include patching the existing hole, from the removal of the existing HVAC unit, shall be filled in with masonry block to match existing wall structure. Also, the existing floor tile will be repaired by Union county School personnel.
- B. The HVAC units have been relocated to the east wall of each classroom.
- C. See New Work Key Note #4.
- D. See new New Work Key Note #6.
- E. See revised "Ductless System - Sequence of Operation."

3. Refer to Drawing E1, Rev. 1:

- A. The HVAC units have been relocated to the east wall of each classroom.

