

**Project Addendum 1  
(1 page, 0 attachments)**


Project: Plantation Hills Street Improvements

Date: August 29, 2016

The listed corrections should be incorporated into the plans/specifications. All bidders are required to indicate on the outside of their proposal envelope the receipt of this information by giving the date and the addenda number.

Description of Corrections:

1. All PVC pipe shall be SDR-26.



---

City of Lakeland  
Emily Harrell, P.E., City Engineer

8/29/16  
Date